

SECTION 22 13 20**OIL-WATER SEPARATORS****PART 1 GENERAL**

1.01 SCOPE

Oil-water separators are required wherever wastewater sources contain petroleum products.

1.02 SUBMITTALS

Submit shop drawings and manufacturer's literature to the AW Project Manager for approval in accordance with Section - Submittals.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Oil-water separators shall be pre-manufactured, pre-cast concrete units designed specifically for separating petroleum products from wastewater.
- B. Provide a minimum storage capacity of 500 gallons.

PART 3 EXECUTION

3.01 DESIGN

- A. Oil-water separators are to be designed for peak flow.
- B. All design calculations and system designs shall be submitted to American Water for review and approval.

3.02 DELIVERY AND STORAGE

- A. Inspect materials delivered to site for damage; unload and store with minimum handling.
- B. Store materials on-site within enclosures or under protective coatings to protect against inclement weather and direct sunlight.

3.03 INSTALLATION

- A. Oil-water separators shall be installed as shown on the Drawings and in strict accordance with the manufacturer's recommendations.
- B. Provide ease of access for cleaning and inspection, accounting for vehicle access.
- C. If required by AW Project Manager, provide services of technical representative of manufacturer available on site during installation of valves.
- D. Only waste from oil producing sources shall flow through the oil-water separators. All oil-water separators shall be located upstream of the location where human waste enters the service line. Sanitary wastes and other wastes shall flow through a separate lateral and connect to the receiving main.

3.04 QUALITY ASSURANCE AND TESTING

- A. The oil-water separator shall be fabricated, inspected, and tested for leakage before shipment from the factory as a completely assembled system ready for installation.
- B. Conduct pressure and leakage tests as required by Section 33 01 10.13.

END OF SECTION 22 13 20