



## FIRE HYDRANT CONSTRUCTION METER DETAIL

**NOTES:**

1. USE OF HYDRANT REQUIRES AUTHORIZATION FROM AMERICAN WATER AND OTHER APPLICABLE AGENCIES.
2. METER AND BACKFLOW DEVICES SHALL BE FULLY SUPPORTED WHEN CONNECTED TO THE FIRE HYDRANT.
3. DOCUMENTATION OF METER AND BACKFLOW CERTIFICATION TO BE PROVIDED TO AMERICAN WATER.
4. METER AND BACKFLOW DEVICES SHALL BE TESTED ANNUALLY ACCORDING TO THE MANUFACTURER'S RECOMMENDATION.
5. CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE TO THE FIRE HYDRANT DURING INSTALLATION, USE, AND REMOVAL.

REVISIONS
6/13 - MSG EDITS

<b>AMERICAN WATER MILITARY SERVICES GROUP CIVIL FIRE HYDRANT CONSTRUCTION METER DETAIL</b>	
<small>AMERICAN WATER MILITARY SERVICES GROUP MT LAUREL, NJ 08054</small>	
<small>AMERICAN WATER M.S.G. 330 FELLOWSHIP ROAD MT LAUREL, NJ 08054</small>	
<small>DRAWN BY J. ABRERA PROJECT ENG'R J. DERUSSO APPROVED</small>	<small>DATE 05-04-2010 PROJECT N/A USE DIMENSIONS ONLY SCALE N.T.S.</small>
<small>USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES</small>	<b>MSG-W-10</b>

FINAL

MSG-W-10