



CONNECTION TO EXISTING MANHOLE

NOTES:

1. CORE DRILL NEW PIPE OPENING.
2. INSERT NEW FLEXIBLE CONNECTOR.
3. AFTER INSERTION OF NEW PIPE, MANHOLE SHALL BE VACUUM TESTED IN ACCORDANCE WITH SPECIFICATIONS.

* BRICK MANHOLES CAN NOT BE CORE DRILLED

REVISIONS
6/13 - MSG EDITS
01/16 - MSG EDITS

**AMERICAN WATER MILITARY SERVICES GROUP
CIVIL
CONNECTION TO EXISTING MANHOLE
DETAIL**

AMERICAN WATER MILITARY SERVICES GROUP
MT LAUREL, NJ 08054

AMERICAN WATER M.S.G.
330 FELLOWSHIP ROAD
MT LAUREL, NJ 08054



DRAWN BY J. ABRERA
PROJECT ENG'R PDK
APPROVED

DATE 04-30-2010
PROJECT N/A

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

MSG-WW-12

FINAL

MSG-WW-12