


## SANITARY FORCE MAIN CLEANOUT DETAIL

### NOTES:

1. VALVES, VALVE BOXES AND VALVE EXTENSIONS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE STANDARD WATER DETAILS.
2. VALVE MARKER POSTS SHALL MEET THE SAME REQUIREMENTS AS SHOWN IN THE WATER DETAILS AND BE PAINTED AS SPECIFIED IN THE STANDARD CONSTRUCTION NOTES.
3. ALL DIP AND FITTING SHALL BE PROTECTOR 401 EPOXY COATED. ALL PIPE AND FITTINGS SHALL BE RESTRAINED JOINT.



TYPICAL SCHEMATIC PLAN VIEW

REVISIONS
6/13 - MSG EDITS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP  
CIVIL  
SANITARY FORCE MAIN CLEANOUT  
DETAIL

AMERICAN WATER MILITARY SERVICES GROUP  
MT LAUREL, NJ 08054

AMERICAN WATER M.S.G.  
330 FELLOWSHIP ROAD  
MT LAUREL, NJ 08054



DRAWN BY PDK  
PROJECT ENG'R PDK  
APPROVED

DATE 08-10-2013  
PROJECT N/A

USE DIMENSIONS ONLY  
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
FOR CONSTRUCTION PURPOSES

MSG-WW-19

FINAL

MSG-W-19