

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK SOUTH WATER (14D)</b> <b>PWS # 1115065</b>			Jan	2019	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	SODIUM HYPOCHLORITE GAL USED	OTA RESIDUAL CHLORINE					PH	FLUORIDE	PHOSPHATE
			FREE	TOTAL						
1	138	10	1.84	1.95	7.5	0.6	3.05		14D	4,168
2	0	0	1.76	1.94	7.4	0.5	3.28			
3	260	15	1.70	2.20	7.5	0.7	2.93			
4	156	15	1.82	2.08	7.4	0.7	2.86			
5	0	0	1.83	1.87	7.6	0.7	2.64			
6	0	0	1.69	1.87	7.6	0.8	2.67			
7	0	0	1.77	2.01	7.4	0.7	2.71			
8	294	20	1.86	2.11	7.3	0.8	3.11			
9	230	20	1.90	2.03	7.4	0.8	2.79			
10	221	20	1.38	1.79	7.4	0.8	2.82			
11	143	9	1.37	1.74	7.5	0.9	2.81			
12	0	0	1.44	1.66	7.5	0.9	2.77			
13	0	0	1.42	1.61	7.7	0.9	2.92			
14	0	0	1.49	2.01	7.5	0.9	2.21			
15	305	15	1.71	1.91	7.3	0.7	3.28			
16	247	15	1.54	2.20	7.5	0.9	2.40			
17	237	20	1.77	2.02	7.3	0.8	2.40			
18	179	15	1.77	1.93	7.3	0.7	2.69			
19	0	0	1.07	1.82	7.4	0.9	2.70			
20	0	0	1.69	1.70	7.4	0.7	2.23			
21	0	0	1.62	1.74	7.5	1.0	2.67			
22	0	0	1.38	1.89	7.4	0.8	2.34			
23	317	25	1.59	1.95	7.4	0.8	2.16			
24	189	15	1.71	2.02	7.5	0.7	1.86			
25	151	10	1.66	1.90	7.5	0.7	2.32			
26	0	0	1.65	1.75	7.6	0.9	2.57			
27	0	0	1.49	1.71	7.6	0.9	2.78			
28	64	0	1.55	2.10	7.5	0.8	3.30			
29	168	15	1.37	1.81	7.5	0.9	3.30			
30	564	75	1.87	2.20	7.5	1.0	3.30			
31	173	4	1.96	2.20	7.4	0.9	3.26			
TOTAL	4036	318								
MAX	564	75	1.96	2.20	7.7	1.0	3.30			
MIN	0	0	1.07	1.61	7.3	0.5	1.86			
AVG	130	10	1.63	1.93	7.5	0.8	2.75			
PREPARED BY <i>Patrick O'Hara (American Water)</i>					DATE <i>1/31/2019</i>		APPROVED BY <i>Bryan M Raisor</i>		DATE <i>1/31/2019</i>	

FP FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)