

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK SOUTH WATER (14D)</b> <b>PWS # 1115065</b>			Mar	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.								WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
DATE	DISTRIBUTION WATER 1000 GAL	SODIUM HYPOCHLORITE GAL USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	19	5	1.69	1.84	7.7	1.0	2.94		14D	3,451
2	0	0	1.95	2.20	7.6	1.0	3.00			
3	223	15	1.64	1.88	7.7	0.9	3.05			
4	126	10	1.83	1.97	7.6	0.8	3.04			
5	0	0	1.73	2.14	7.5	1.0	3.40			
6	231	15	1.52	1.90	7.6	1.0	2.94			
7	0	0	1.76	1.80	7.4	0.9	3.07		Grand Total	3,451
8	0	0	1.71	1.75	7.4	1.0	3.41			
9	0	0	1.37	1.70	7.7	1.0	3.06			
10	0	0	1.47	1.76	7.7	1.1	2.85			
11	244	19	1.41	1.82	7.6	1.1	2.82			
12	441	25	1.38	1.81	7.5	1.0	2.83			
13	204	23	1.15	1.27	7.6	0.9	2.94			
14	0	0	1.49	1.68	7.5	1.0	3.27			
15	0	0	1.45	1.58	7.4	1.2	3.32			
16	0	0	1.34	1.53	7.4	1.0	3.13			
17	0	0	1.32	1.74	7.5	1.1	2.86			
18	251	12	1.35	1.55	7.5	1.0	2.95			
19	0	0	1.20	1.30	7.6	1.1	3.16			
20	288	20	0.91	0.99	7.5	1.2	3.28			
21	0	0	1.15	1.22	7.5	1.0	2.97			
22	0	0	1.02	1.16	7.6	1.0	3.03			
23	333	25	1.14	1.32	7.4	1.0	3.36			
24	68	5	1.49	1.61	7.3	0.9	3.18			
25	306	20	1.35	1.66	7.5	0.9	3.27			
26	0	0	1.39	1.54	7.4	1.0	3.06			
27	298	25	1.87	2.08	7.5	1.0	2.96			
28	0	0	1.96	2.06	7.4	0.8	3.28			
29	0	0	1.93	2.02	7.4	0.9	3.08			
30	0	0	1.91	2.04	7.5	1.0	3.07			
31	348	30	1.70	1.72	7.5	0.9	2.80			
TOTAL	3380	249								
MAX	441	30	1.96	2.20	7.7	1.2	3.41			
MIN	0	0	0.91	0.99	7.3	0.8	2.80			
AVG	109	8	1.50	1.70	7.5	1.0	3.08			
PREPARED BY <i>Patrick O'Hara (American Water)</i>					DATE <i>3/31/2020</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>3/31/2020</i>	

5.056 7.735

**FP**

FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)