

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK SOUTH WATER (14D) PWS # 1115065			Mar	2019	
For use of this form, see AR 420-46; the proponent										
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	SODIUM HYPOCHLORITE GAL USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	139	10	1.23	1.29	7.4	0.9	2.53		14D	4,931
2	0	0	1.08	1.18	7.5	0.9	2.57			
3	0	0	1.09	1.10	7.5	1.0	2.57			
4	0	0	1.14	1.62	7.4	0.8	2.47			
5	269	15	1.25	1.68	7.4	1.1	2.57			
6	95	5	1.21	1.22	7.4	1.1	2.84			
7	229	15	1.18	1.56	7.4	1.3	2.97		Grand Total	4,931
8	107	15	1.08	1.28	7.4	1.2	2.95			
9	0	0	1.08	1.25	7.6	1.2	2.71			
10	0	0	1.08	1.10	7.6	1.2	2.79			
11	0	0	0.82	1.18	7.5	1.1	2.58			
12	597	25	1.56	1.57	7.4	1.1	2.88			
13	221	10	0.98	1.38	7.5	1.0	2.55			
14	232	10	1.28	1.32	7.5	1.0	2.45			
15	116	1	0.98	1.37	7.5	1.0	2.44			
16	0	0	1.16	1.17	7.4	1.1	2.55			
17	0	0	0.96	1.15	7.4	1.0	2.62			
18	0	0	1.07	1.21	7.4	0.9	2.44			
19	316	19	1.07	1.26	7.4	0.9	2.96			
20	198	20	0.85	1.14	7.4	1.3	2.94			
21	230	10	1.00	1.43	7.4	1.1	2.63			
22	181	10	1.14	1.25	7.4	1.1	3.30			
23	0	0	1.27	1.30	7.2	1.2	3.21			
24	0	0	0.94	1.05	7.5	1.2	2.73			
25	0	0	0.96	1.44	7.5	1.2	3.26			
26	281	25	1.17	1.61	7.5	1.1	2.61			
27	557	40	0.99	1.41	7.3	1.1	2.57			
28	522	30	1.23	1.63	7.4	1.1	2.59			
29	491	35	1.04	1.25	7.4	1.1	2.55			
30	0	0	1.09	1.25	7.4	1.2	2.69			
31	0	0	1.07	1.19	7.5	1.1	2.76			
TOTAL	4781	295								
MAX	597	40	1.56	1.68	7.6	1.3	3.30			
MIN	0	0	0.82	1.05	7.2	0.8	2.44			
AVG	154	10	1.10	1.32	7.4	1.1	2.72			
PREPARED BY <i>Patrick O'Hara (American Water)</i>					DATE <i>3/31/2019</i>		APPROVED BY <i>Bryan M Raisor</i>		DATE <i>3/31/2019</i>	

FP FORM
1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)