

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK NORTH HOUSING WATER (16D)</b> <b>PWS # 1115087</b>					
For use of this form, see AR 420-46; the proponent									<b>Apr</b>	<b>2019</b>
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS					REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE			
			FREE	TOTAL						
1	0	0	0.75	0.78	7.1	1.0	1.85			
2	265	15	1.54	1.68	7.1	1.1	1.74	15D	1,227	
3	10	0	1.60	1.71	7.2	1.0	1.67	16D	1,181	
4	0	0	1.51	1.52	7.2	0.9	1.66			
5	217	14	1.55	1.60	7.1	1.0	1.64			
6	0	0	1.44	1.47	7.2	1.0	1.61			
7	0	0	1.35	1.41	7.3	1.2	1.84			
8	286	15	1.21	1.26	7.3	1.0	1.58	Grand Total	2,408	
9	0	0	1.17	1.22	7.4	0.8	1.77			
10	0	0	1.14	1.19	7.3	0.9	1.98			
11	270	13	1.15	1.22	7.2	1.0	1.83			
12	115	7	1.45	1.54	7.3	0.9	1.66			
13	0	0	1.34	1.42	7.2	0.9	1.61			
14	0	0	1.55	1.60	7.3	1.0	1.53			
15	0	0	1.20	1.36	7.2	1.0	1.63			
16	71	18	1.41	1.44	7.2	0.9	1.54			
17	0	0	1.30	1.39	7.3	1.1	1.58			
18	0	0	1.30	1.32	7.3	1.1	1.69			
19	289	7	1.04	1.08	7.3	1.0	1.89			
20	3	0	1.25	1.28	7.2	1.0	2.00			
21	1	0	1.18	1.24	7.2	1.0	1.68			
22	274	6	1.18	1.19	7.3	0.9	1.80			
23	4	0	1.20	1.30	7.2	1.0	1.76			
24	4	0	1.23	1.35	7.1	1.0	1.79			
25	310	7	1.22	1.23	7.1	0.8	1.79			
26	5	0	1.03	1.24	7.2	0.8	1.90			
27	5	0	1.72	1.79	7.2	0.7	1.86			
28	279	6	1.33	1.41	7.3	0.9	2.07			
29	0	0	1.12	1.25	7.3	0.9	1.98			
30	0	0	1.05	1.12	7.3	0.9	1.96			

TOTAL	2408	108							
MAX	310	18	1.72	1.79	7.4	1.2	2.07		
MIN	0	0	0.75	0.78	7.1	0.7	1.53		
AVG	80	4	1.28	1.35	7.2	1.0	1.76		
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>4/30/2019</i>		APPROVED BY <i>Bryan M Raisor</i>		DATE <i>4/30/2019</i>

**FP**

FORM

1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)