

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
<i>(Water - General)</i>					FORT POLK NORTH HOUSING WATER (16D) PWS # 1115087			Dec	2019	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	240	6	1.25	1.28	7.5	1.5	2.02		15D	2,147
2	0	0	1.20	1.27	7.4	1.5	1.71		16D	639
3	175	4	1.35	1.39	7.2	1.8	2.29			
4	0	0	1.18	1.34	7.4	1.7	2.00			
5	0	0	1.25	1.37	7.4	1.6	1.89			
6	230	10	1.30	1.34	7.4	1.2	1.79			
7	0	0	1.31	1.36	7.3	1.5	1.98			
8	0	0	1.05	1.14	7.2	1.6	1.81			
9	277	14	1.54	1.69	7.3	1.2	1.81			
10	0	0	1.44	1.49	7.3	1.3	1.68			
11	0	0	1.20	1.34	7.6	1.3	1.80			
12	265	12	1.63	1.76	7.3	1.3	1.65			
13	147	7	1.63	1.71	7.2	1.0	1.66			
14	0	0	1.39	1.41	7.5	1.3	1.72			
15	0	0	1.41	1.47	7.5	1.1	1.73			
16	0	0	1.78	1.80	7.1	0.9	1.65			
17	379	14	1.43	1.51	7.5	1.1	1.65			
18	117	6	1.46	1.50	7.5	1.1	1.44			
19	0	0	1.38	1.49	7.5	1.3	1.62			
20	263	12	1.72	1.75	7.3	1.0	1.77			
21	0	0	1.41	1.45	7.3	1.0	1.64			
22	0	0	1.18	1.32	7.4	1.1	1.47			
23	0	0	1.40	1.44	7.6	1.1	1.75			
24	260	14	1.61	1.70	7.4	1.1	1.53			
25	0	0	1.53	1.55	7.4	1.1	1.57			
26	0	0	1.30	1.50	7.3	1.1	1.52			
27	209	11	1.83	1.84	7.2	1.1	1.64			
28	0	0	1.28	1.41	7.4	0.8	1.48			
29	0	0	1.30	1.45	7.4	0.8	1.74			
30	0	0	1.74	1.94	7.4	1.0	1.56			
31	224	6	1.42	1.71	7.4	1.1	1.81			
TOTAL	2786	116								
MAX	379	14	1.83	1.94	7.6	1.8	2.29			
MIN	0	0	1.05	1.14	7.1	0.8	1.44			
AVG	90	4	1.42	1.51	7.4	1.2	1.72			
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>12/31/2019</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>12/31/2019</i>	

5.155 4.843 7.540

FP

FORM
1 JULY 73 **4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)