FACILITIES ENGINEERING OPERATING LOG

(Water - General)

For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.

INSTALLATION : FORT POLK, LA

FORT POLK NORTH HOUSING WATER (16D)
PWS # 1115087

MONTH	YEAR
Feb	**2019**

DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS: OTA RESIDUAL CHLORINE FREE	OTA RESIDUAL CHLORINE TOTAL	PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
1	132	11	1.87	2.10	7.2	1.0	1.64		**15D**	765
2	0	0	1.32	1.47	7.0	1.0	1.93		**16D**	1,474
3	3	0	1.27	1.42	7.1	1.2	1.86			
4	0	0	1.27	1.38	7.0	1.0	1.57			
5	159	12	1.19	1.30	7.2	0.9	1.69			
6	0	0	1.18	1.21	7.2	0.9	1.71			
7	119	9	1.13	1.18	7.2	0.8	1.63		**Grand Total**	2,239
8	92	7	1.20	1.32	7.0	0.9	1.50			
9	0	0	1.20	1.24	7.2	1.0	1.50			
10	0	0	1.17	1.22	7.3	1.0	1.70			
11	19	0	1.66	1.72	7.2	0.9	1.71			
12	174	13	1.27	1.32	7.3	0.9	1.56			
13	0	0	1.03	1.14	7.1	1.2	1.64			
14	232	9	1.29	1.31	7.4	1.0	1.65			
15	136	5	1.90	2.05	7.0	1.2	1.82			
16	0	0	1.44	1.77	7.2	1.0	1.62			
17	0	0	1.25	1.46	7.1	1.1	1.98			
18	201	7	1.59	1.65	7.1	1.2	1.71			
19	0	0	1.13	1.36	7.2	1.0	2.05			
20	283	10	1.97	2.15	7.0	1.0	1.94			
21	0	0	1.81	2.12	7.1	1.1	1.67			
22	188	5	1.83	2.03	7.2	1.0	1.86			
23	0	0	1.37	1.39	7.0	1.0	1.95			
24	0	0	1.35	1.56	7.1	0.8	1.78			
25	256	7	1.57	1.60	7.0	1.2	1.94			
26	0	0	1.52	1.54	7.1	1.0	1.95			
27	173	4	1.39	1.43	7.1	1.2	1.75			
28	72	3	1.36	1.43	7.1	1.0	1.80			

TOTAL	2239	102					
MAX	283	13	1.97	2.15	7.4	1.2	2.05
MIN	0	0	1.03	1.14	7.0	0.8	1.50
AVG	80	4	1.41	1.53	7.1	1.0	1.75

PREPARED BY	DATE	APPROVED BY	DATE
Noah Belcher (American Water)	*2/28/2019*	*Bryan M Raisor*	*2/28/2019*

FP FORM **4141**

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)