

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK NORTH HOUSING WATER (16D) PWS # 1115087					
For use of this form, see AR 420-46; the proponent								Jan	2019	
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	3	0	1.47	1.54	7.1	1.2	1.60			
2	171	5	1.59	1.73	7.2	1.2	1.63	15D	1,811	
3	28	0	1.42	1.44	7.3	1.0	1.58	16D	1,080	
4	136	5	1.27	1.33	7.2	1.6	1.56			
5	170	5	1.15	1.16	7.2	1.1	1.49			
6	6	0	1.08	1.13	7.2	1.1	1.48			
7	0	3	1.09	1.25	7.1	1.2	1.22			
8	271	9	1.15	1.21	7.1	1.2	1.56	Grand Total	2,891	
9	0	0	1.07	1.13	7.2	1.1	1.65			
10	0	0	1.30	1.39	7.3	1.1	1.51			
11	303	0	1.42	1.67	7.1	0.8	1.35			
12	0	0	1.03	1.17	7.3	1.1	1.82			
13	0	0	1.02	1.87	7.3	1.2	1.63			
14	0	0	1.13	1.30	7.0	1.0	1.57			
15	306	11	1.14	1.15	7.2	1.0	1.56			
16	0	0	1.09	1.17	7.1	1.1	1.61			
17	0	0	1.18	1.37	7.1	0.9	1.46			
18	383	17	1.38	1.41	7.1	1.1	1.58			
19	0	0	1.22	1.42	7.1	0.7	1.68			
20	0	0	1.12	1.18	7.2	0.9	1.65			
21	192	9	1.22	1.40	7.2	1.1	1.57			
22	0	0	1.34	1.47	7.3	1.2	1.62			
23	176	7	1.06	1.43	7.3	1.1	1.69			
24	0	0	1.25	1.31	7.3	0.8	1.90			
25	209	6	1.40	1.50	7.3	1.0	2.68			
26	3	0	1.00	1.25	7.4	1.1	2.62			
27	2	0	1.09	1.28	7.3	1.1	1.74			
28	306	10	1.52	1.77	7.1	0.7	1.78			
29	72	2	1.27	1.56	7.1	1.0	1.68			
30	107	3	1.24	1.51	7.2	0.7	1.79			
31	47	2	1.40	1.91	7.3	1.0	1.77			

TOTAL	2891	94							
MAX	383	17	1.59	1.91	7.4	1.6	2.68		
MIN	0	0	1.00	1.13	7.0	0.7	1.22		
AVG	93	3	1.23	1.40	7.2	1.0	1.68		
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>1/31/2019</i>		APPROVED BY <i>Bryan M Raisor</i>		DATE <i>1/31/2019</i>

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)