

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK NORTH HOUSING WATER (16D)</b> <b>PWS # 1115087</b>			Jan	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS					REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE			
			FREE	TOTAL						
1	0	0	1.30	1.33	7.3	1.1	1.74	15D	2,177	
2	0	0	1.18	1.47	7.4	0.8	1.56	16D	877	
3	279	9	1.34	1.67	7.3	0.9	2.08			
4	0	0	1.33	1.39	7.4	1.0	1.76			
5	0	0	1.39	1.40	7.5	1.0	1.91			
6	297	9	1.44	1.52	7.3	1.1	2.08			
7	0	0	1.42	1.50	7.5	1.0	1.92	Grand Total	3,054	
8	0	0	1.35	1.47	7.5	0.9	1.86			
9	0	0	1.50	1.54	7.4	1.1	2.12			
10	405	13	1.44	1.51	7.2	0.8	1.75			
11	0	0	1.39	1.45	7.4	0.8	1.87			
12	0	0	1.07	1.66	7.5	1.0	2.15			
13	264	12	1.48	1.58	7.4	1.0	1.93			
14	0	0	1.47	1.59	7.5	0.9	1.74			
15	0	0	1.38	1.42	7.6	0.9	1.90			
16	280	13	1.78	1.85	7.2	0.8	1.50			
17	107	6	1.53	1.56	7.3	0.9	1.47			
18	0	0	1.27	1.32	7.4	1.0	1.63			
19	0	0	1.18	1.30	7.4	1.1	1.55			
20	229	8	1.12	1.27	7.3	1.1	1.66			
21	0	0	1.49	1.56	7.4	1.0	1.55			
22	261	12	1.33	1.99	7.4	1.1	1.64			
23	0	0	1.40	1.74	7.4	1.1	1.57			
24	268	16	1.46	2.10	7.4	1.1	1.62			
25	0	0	1.31	1.47	7.3	1.0	1.59			
26	0	0	1.49	1.57	7.3	0.9	1.68			
27	266	14	1.48	1.63	7.2	0.8	1.61			
28	0	0	1.46	1.67	7.3	1.0	1.65			
29	0	0	1.57	1.67	7.3	1.0	1.69			
30	284	15	1.12	1.30	7.3	0.9	1.54			
31	114	6	1.46	1.62	7.3	0.9	1.64			

TOTAL	3054	133					
MAX	405	16	1.78	2.10	7.6	1.1	2.15
MIN	0	0	1.07	1.27	7.2	0.8	1.47
AVG	99	4	1.38	1.55	7.4	1.0	1.74

PREPARED BY	DATE	APPROVED BY	DATE
<i>Noah Belcher (American Water)</i>	<i>1/31/2020</i>	<i>Bradley Day</i>	<i>1/31/2020</i>

**FP**

FORM

**4141**

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)