

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
<i>(Water - General)</i>					FORT POLK NORTH HOUSING WATER (16D) PWS # 1115087					
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	0	0	1.32	1.39	7.5	1.0	1.63		15D	2,267
2	279	11	1.38	1.50	7.2	0.9	1.69		16D	1,277
3	0	0	1.09	1.25	7.4	0.8	1.66			
4	0	0	1.10	1.18	7.4	1.0	1.63			
5	287	12	1.23	1.29	7.3	0.8	1.60			
6	174	10	1.11	1.13	7.2	0.9	1.64			
7	0	0	1.26	1.48	7.4	1.0	1.58			
8	0	0	1.08	1.31	7.5	1.0	1.69			
9	284	12	1.37	1.43	7.3	0.9	1.51			
10	372	11	1.74	1.81	7.5	0.9	1.93			
11	0	0	1.53	1.60	7.5	0.9	1.73			
12	0	0	1.42	1.51	7.5	0.8	1.63			
13	291	10	1.44	1.51	7.5	1.0	1.85			
14	0	0	1.43	1.49	7.5	1.0	1.86			
15	0	0	1.45	1.52	7.5	0.9	1.94			
16	301	10	1.48	1.52	7.6	0.9	2.06			
17	0	0	1.54	1.56	7.5	0.9	1.85			
18	0	0	1.49	1.53	7.5	0.9	1.93			
19	313	8	1.61	1.75	7.5	0.9	1.98			
20	160	9	1.82	1.90	7.1	0.8	1.60			
21	0	0	1.48	1.52	7.4	0.9	1.99			
22	0	0	1.65	1.71	7.5	1.0	1.91			
23	313	15	1.11	1.52	7.4	0.9	1.76			
24	0	0	1.30	1.39	7.4	0.8	1.64			
25	0	0	1.14	1.17	7.2	0.8	1.67			
26	332	16	1.35	1.37	7.4	0.8	1.63			
27	137	8	1.08	1.18	7.2	0.8	1.58			
28	0	0	1.27	1.36	7.4	0.8	1.62			
29	0	0	1.22	1.37	7.5	0.8	1.64			
30	301	11	1.19	1.25	7.4	0.9	1.76			
31	0	0	1.29	1.34	7.4	0.9	1.64			
Grand Total										
3,544										
TOTAL	3544	143								
MAX	372	16	1.82	1.90	7.6	1.0	2.06			
MIN	0	0	1.08	1.13	7.1	0.8	1.51			
AVG	114	5	1.35	1.45	7.4	0.9	1.74			
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>3/31/2020</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>3/31/2020</i>	

5.209 5.056 7.735

FP FORM
1 JULY 73 **4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)