

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK NORTH HOUSING WATER (16D) PWS # 1115087					
For use of this form, see AR 420-46; the proponent								Mar	2019	
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	89	7	1.35	1.56	7.1	1.1	1.77		15D	1,620
2	2	0	1.34	1.41	7.2	1.0	1.52		16D	1,315
3	2	0	1.25	1.42	7.1	1.1	1.76			
4	0	0	1.38	1.51	7.0	1.1	1.63			
5	250	14	1.28	1.38	7.0	1.1	1.78			
6	4	0	1.34	1.44	7.1	1.0	1.71			
7	0	0	1.51	1.60	7.1	0.9	1.42		Grand Total	2,935
8	319	13	1.83	2.05	7.1	1.0	1.57			
9	0	0	1.17	1.31	7.3	1.2	1.70			
10	0	0	1.26	1.27	7.3	1.1	1.68			
11	330	14	1.05	1.08	7.1	1.0	1.61			
12	0	0	1.52	1.74	7.0	1.1	1.57			
13	212	8	1.10	1.24	7.0	1.1	1.62			
14	117	5	1.74	1.76	7.1	1.2	1.59			
15	155	5	1.96	2.15	7.1	1.2	1.77			
16	0	0	1.88	2.05	7.2	1.2	1.30			
17	128	5	1.61	1.93	7.3	1.2	1.55			
18	0	0	1.41	1.53	7.3	1.2	1.50			
19	0	0	1.47	1.50	7.1	1.5	1.52			
20	292	10	1.76	1.76	7.1	1.2	1.56			
21	0	0	1.44	1.60	7.2	1.1	1.79			
22	293	11	1.56	1.66	7.4	1.5	1.71			
23	0	0	1.51	1.56	7.0	1.2	1.73			
24	0	0	1.48	1.50	7.2	1.0	1.86			
25	0	0	1.63	1.79	7.2	1.1	2.06			
26	315	9	1.59	1.84	7.1	1.2	1.82			
27	8	0	1.67	1.73	7.0	0.9	1.74			
28	253	16	1.66	1.82	7.1	0.9	1.69			
29	148	8	1.62	1.66	7.1	1.1	1.55			
30	14	0	1.71	1.81	7.1	1.1	1.82			
31	4	0	1.71	1.80	7.1	1.0	1.69			

TOTAL	2935	125								
MAX	330	16	1.96	2.15	7.4	1.5	2.06			
MIN	0	0	1.05	1.08	7.0	0.9	1.30			
AVG	95	4	1.51	1.63	7.1	1.1	1.66			
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>3/31/2019</i>		APPROVED BY <i>Bryan M Raisor</i>		DATE <i>3/31/2019</i>	

FP

FORM

1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)