

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
<i>(Water - General)</i>					<b>FORT POLK NORTH HOUSING WATER (16D)</b> <b>PWS # 1115087</b>					
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.								Sep	2019	
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	0	0	1.69	1.72	7.6	1.4	2.07			
2	0	0	1.82	1.88	7.5	1.4	2.01			
3	329	9	1.15	1.30	7.5	1.4	2.08			
4	0	0	1.29	1.42	7.5	1.2	2.32			
5	0	0	0.98	1.22	7.5	1.4	2.36			
6	269	7	1.43	1.52	7.5	0.9	2.31			
7	20	3	1.23	1.24	7.3	1.0	2.48			
8	3	0	1.13	1.17	7.3	1.0	2.54			
9	275	16	1.86	2.07	7.2	0.5	1.67			
10	6	0	1.31	1.46	7.2	1.0	1.74			
11	9	0	1.40	1.49	7.3	0.9	1.92			
12	0	0	1.26	1.33	7.3	1.0	1.89			
13	331	17	1.49	1.55	7.2	0.8	1.65			
14	0	0	1.41	1.47	7.2	0.9	1.53			
15	7	0	1.48	1.52	7.3	1.1	1.69			
16	0	0	1.78	1.89	7.4	1.3	2.03			
17	289	14	1.21	1.26	7.2	0.8	1.71			
18	0	0	1.20	1.24	7.2	1.4	1.58			
19	203	10	1.89	2.01	7.1	1.4	1.05			
20	74	4	1.48	1.56	7.2	1.5	1.50			
21	0	0	1.19	1.20	7.2	1.1	1.65			
22	0	0	1.08	1.20	7.3	1.1	1.74			
23	0	0	0.99	1.12	7.2	1.5	1.58			
24	312	11	1.08	1.31	7.4	1.0	1.51			
25	4	2	1.03	1.20	7.4	0.9	1.86			
26	0	0	1.11	1.13	7.2	1.0	1.85			
27	258	7	1.47	1.60	7.4	1.0	1.74			
28	0	0	1.57	1.87	7.4	1.0	2.01			
29	0	0	1.64	1.88	7.5	1.0	1.76			
30	276	8	1.68	1.85	7.4	1.3	2.14			

TOTAL	2665	108					
MAX	331	17	1.89	2.07	7.6	1.5	2.54
MIN	0	0	0.98	1.12	7.1	0.5	1.05
AVG	89	4	1.38	1.49	7.3	1.1	1.87

PREPARED BY <i>Noah Belcher (American Water)</i>	DATE <i>9/30/2019</i>	APPROVED BY <i>Bradley Day</i>	DATE <i>9/30/2019</i>
---	--------------------------	-----------------------------------	--------------------------

**FP**

FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)