

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK SOUTH WATER (2902) PWS # 1115065			Apr	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	1,920	64	1.34	1.59	6.6	0.8	2.72		7	6,114
2	0	0	1.32	1.52	6.5	0.7	2.80		8	6,779
3	2,187	77	1.54	1.82	6.5	0.7	2.66		9	4,702
4	0	0	1.27	1.54	6.6	0.7	2.78		11	4,486
5	0	0	1.53	1.79	6.5	1.2	2.70		12	7,093
6	2,466	88	1.41	1.74	6.4	0.8	2.75			
7	0	0	1.40	1.60	6.5	0.9	2.64		Grand Total	29,174
8	2,206	63	0.81	1.02	6.5	0.5	2.66			
9	783	28	1.13	1.34	6.5	0.7	2.85			
10	0	0	1.21	1.40	6.5	0.8	2.85			
11	2,275	79	1.40	1.61	6.5	0.8	2.68			
12	0	0	1.22	1.37	6.5	0.8	2.83			
13	1,867	69	1.40	1.68	6.5	0.8	2.68			
14	0	0	1.27	1.44	6.5	0.7	2.77			
15	1,851	67	1.55	1.79	6.4	0.8	2.66			
16	0	0	1.36	1.52	6.6	0.8	2.78			
17	1,818	68	1.48	1.72	6.5	0.9	2.63			
18	0	0	1.11	1.45	6.5	0.9	3.64			
19	1,934	65	1.27	1.65	6.6	0.9	2.83			
20	0	0	1.36	1.61	6.4	0.9	2.80			
21	1,883	73	1.43	1.59	6.5	1.0	2.71			
22	0	0	1.34	1.52	6.5	1.1	2.88			
23	2,268	85	1.35	1.62	6.5	1.0	2.71			
24	0	0	1.30	1.52	6.5	1.1	2.75			
25	2,182	75	1.33	1.60	6.5	1.0	2.74			
26	0	0	1.32	1.49	6.6	1.0	2.87			
27	2,007	69	1.26	1.56	6.6	0.9	2.64			
28	0	0	1.27	1.54	6.6	0.9	2.82			
29	1,616	58	1.45	1.69	6.5	1.0	2.69			
30	0	0	1.28	1.46	6.5	1.0	2.75			

4.702 4.486 7.093

TOTAL	29263	1028					
MAX	2466	88	1.55	1.82	6.6	1.2	3.64
MIN	0	0	0.81	1.02	6.4	0.5	2.63
AVG	975	34	1.32	1.56	6.5	0.9	2.78

PREPARED BY	DATE	APPROVED BY	DATE
Bradley S Day (American Water)	4/30/2020	Bradley Day	4/30/2020

FORM
FP **4141**
1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)