

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK SOUTH WATER (2902)</b> <b>PWS # 1115065</b>					
For use of this form, see AR 420-46; the proponent									<b>Apr</b>	<b>2019</b>
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS					REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE			
			FREE	TOTAL						
1	1,080	37	1.01	1.40	6.6	1.2	2.85		7	0
2	770	28	1.01	1.20	6.5	1.0	3.01		8	7,628
3	698	26	1.44	1.84	6.5	1.3	2.70		9	5,321
4	597	22	1.01	2.04	6.5	1.4	2.83		11	5,055
5	440	15	1.00	1.31	6.4	1.3	2.86		12	7,761
6	868	29	0.99	1.33	6.5	1.1	2.78			
7	949	31	1.29	1.69	6.4	1.2	2.90			
8	956	31	0.92	1.32	6.4	1.1	2.81		<b>Grand Total</b>	<b>25,765</b>
9	932	30	0.96	1.18	6.4	1.2	3.30			
10	955	32	1.25	1.55	6.5	1.3	2.84			
11	0	0	1.00	1.33	6.5	1.3	2.99			
12	996	34	1.10	1.44	6.5	0.9	2.83			
13	1,320	51	1.43	1.47	6.5	1.3	2.54			
14	0	0	1.04	1.05	6.6	1.3	3.00			
15	1,510	55	1.24	1.31	6.5	1.2	3.06			
16	0	0	1.05	1.23	6.5	1.2	2.99			
17	1,700	64	1.59	1.91	6.5	1.2	2.86			
18	0	0	0.79	1.16	6.6	1.3	3.00			
19	0	0	1.17	1.21	6.5	1.2	3.00			
20	2,220	76	1.59	2.11	6.4	1.2	2.81			
21	0	0	1.19	1.65	6.5	1.1	3.00			
22	890	29	1.03	1.81	6.5	1.2	2.95			
23	1,190	47	0.95	0.98	6.5	1.1	2.90			
24	0	0	1.07	1.38	6.5	1.1	2.97			
25	1,680	58	0.84	1.05	6.5	1.1	3.04			
26	0	0	0.74	0.93	6.6	1.1	3.22			
27	2,400	70	0.85	1.03	6.6	1.3	2.82			
28	0	0	0.87	1.06	6.4	1.2	3.08			
29	2,532	77	0.97	1.20	6.3	1.2	2.62			
30	0	0	0.88	0.97	6.4	1.2	3.03			

TOTAL	24683	842								
MAX	2532	77	1.59	2.11	6.6	1.4	3.30			
MIN	0	0	0.74	0.93	6.3	0.9	2.54			
AVG	823	28	1.08	1.37	6.5	1.2	2.92			
PREPARED BY <i>Bradley S Day (American Water)</i>					DATE <i>4/30/2019</i>		APPROVED BY <i>Bryan M. Raisor</i>		DATE <i>4/30/2019</i>	

**FP**

FORM

**4141**

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)