

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK SOUTH WATER (2902) PWS # 1115065			Dec	2019	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	1,325	39	1.45	1.60	6.5	1.3	3.84		7	7,016
2	0	0	1.38	1.56	6.5	1.4	3.76		8	6,728
3	1,683	48	1.05	1.18	6.5	0.9	2.99		9	5,155
4	0	0	1.32	1.44	6.5	1.3	3.38		11	4,843
5	2,742	78	1.14	1.34	6.5	1.1	2.78		12	7,540
6	0	0	1.13	1.30	6.6	1.1	3.11			
7	2,188	59	0.86	1.05	6.4	0.8	2.84		Grand Total	31,282
8	0	0	1.01	1.12	6.5	0.9	3.09			
9	2,380	74	1.18	1.46	6.5	0.8	2.72			
10	0	0	0.98	1.14	6.5	1.1	2.86			
11	1,857	62	1.37	1.65	6.5	1.0	2.62			
12	0	0	1.25	1.39	6.6	0.9	2.77			
13	2,347	79	1.43	1.62	6.5	0.9	2.62			
14	0	0	1.21	1.50	6.6	0.9	2.79			
15	2,294	66	0.86	1.10	6.5	0.9	2.50			
16	486	21	0.88	0.95	6.6	0.9	2.84			
17	1,169	34	0.71	1.24	6.5	1.0	2.79			
18	961	29	0.85	1.31	6.5	1.1	2.64			
19	1,361	44	1.15	1.46	6.6	0.9	2.44			
20	1,014	36	1.27	1.60	6.5	1.0	2.44			
21	0	0	1.19	1.44	6.5	1.1	2.76			
22	1,872	58	1.10	1.43	6.6	1.1	2.25			
23	0	0	1.18	1.35	6.6	1.1	2.11			
24	1,852	62	1.24	1.60	6.5	1.1	4.22			
25	0	0	1.16	1.39	6.5	1.1	2.99			
26	2,010	67	1.33	1.46	6.5	0.9	1.53			
27	0	0	1.05	1.44	6.5	0.9	2.65			
28	2,090	67	1.13	1.41	6.5	0.8	2.25			
29	0	0	1.20	1.41	6.5	0.8	2.25			
30	1,758	56	1.27	1.42	6.5	0.8	2.18			
31	0	0	1.10	1.27	6.5	0.8	2.39			
TOTAL	31389	979								
MAX	2742	79	1.45	1.65	6.6	1.4	4.22			
MIN	0	0	0.71	0.95	6.4	0.8	1.53			
AVG	1013	32	1.14	1.38	6.5	1.0	2.75			
PREPARED BY <i>Bradley S Day (American Water)</i>					DATE <i>12/31/2019</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>12/31/2019</i>	

5.155      4.843      7.540

FP FORM 4141  
1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)