FACILITIES ENGINEERING OPERATING LOG

(Water - General)

For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.

INSTALLATION : FORT POLK, LA

FORT POLK SOUTH WATER (2902)
PWS # 1115065

MONTH	YEAR
Feb	**2019**

DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE	CHEMICAL ANALYSIS					REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
		POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE			
			FREE	TOTAL						
1	810	29	0.80	1.09	6.5	1.3	2.99		**7**	0
2	1,221	37	1.06	1.44	6.4	1.3	3.11		**8**	8,352
3	1,009	31	0.66	4.10	6.4	1.3	3.02		**9**	5,799
4	808	29	0.93	1.03	6.5	1.4	3.10		**11**	5,391
5	966	31	0.76	0.93	6.5	1.2	3.26		**12**	9,354
6	686	24	0.71	1.05	6.5	1.2	3.30			
7	864	28	0.74	1.00	6.5	1.3	3.30		**Grand Total**	28,896
8	845	23	1.17	1.55	6.4	1.3	2.98			
9	805	36	0.80	1.81	6.5	1.2	2.83			
10	785	19	1.39	2.20	6.6	1.1	2.82			
11	1,246	40	0.80	1.13	6.5	1.3	3.05			
12	1,003	31	1.08	1.38	6.4	1.2	3.02			
13	822	30	0.73	0.95	6.4	1.3	3.09			
14	899	26	0.83	1.02	6.5	1.3	3.30			
15	892	30	1.03	1.44	6.5	1.2	3.26			
16	994	31	1.13	1.46	6.4	1.3	3.02			
17	762	25	0.76	0.99	6.5	1.3	3.06			
18	989	31	1.09	1.95	6.5	1.2	2.90			
19	884	21	1.36	2.20	6.5	1.4	2.91			
20	1,032	36	0.72	1.71	6.5	1.4	2.90			
21	727	23	0.78	1.79	6.5	1.3	2.82			
22	645	21	0.95	1.88	6.4	1.3	2.81			
23	1,516	64	1.14	1.97	6.4	1.1	2.86			
24	697	26	1.61	2.03	6.4	1.1	3.02			
25	903	34	0.62	0.83	6.5	1.4	3.00			
26	599	15	1.27	1.72	6.4	1.4	3.30			
27	960	31	0.99	1.99	6.5	1.2	2.86			
28	922	29	1.06	2.11	6.6	1.4	2.77			

TOTAL	25291	831					
MAX	1516	64	1.61	4.10	6.6	1.4	3.30
MIN	599	15	0.62	0.83	6.4	1.1	2.77
AVG	903	30	0.96	1.60	6.5	1.3	3.02

PREPARED BY	DATE	APPROVED BY	DATE
Bradley S Day (American Water)	*2/28/2019*	*Bryan M. Raisor*	*2/28/2019*

FP FORM **4141**

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)