

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK SOUTH WATER (2902) PWS # 1115065			Jan	2019	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE					PH	FLUORIDE	PHOSPHATE
			FREE	TOTAL						
1	884	29	1.46	2.20	6.5	1.1	2.98		7	0
2	341	15	0.86	1.95	6.5	1.6	2.96		8	9,515
3	489	16	0.88	1.71	6.4	1.6	3.04		9	6,720
4	722	21	0.84	1.06	6.6	1.2	3.04		11	6,381
5	1,855	63	0.68	1.16	6.5	1.2	3.02		12	10,543
6	900	28	0.95	1.35	6.5	1.2	2.96			
7	933	30	1.45	1.93	6.5	1.2	3.09			
8	989	38	1.55	2.02	6.5	1.1	2.75			
9	890	27	1.16	1.74	6.5	1.3	3.11			
10	656	26	1.61	2.17	6.5	1.3	3.12			
11	837	25	1.44	2.17	6.5	1.3	2.91			
12	983	34	0.80	1.11	6.6	1.3	3.02			
13	729	24	0.97	1.49	6.5	1.2	2.93			
14	999	38	0.83	1.12	6.5	1.3	3.10			
15	306	9	0.90	1.23	6.5	1.1	3.21			
16	763	30	1.25	1.55	6.5	1.4	3.15			
17	775	25	1.48	1.85	6.5	1.3	3.30			
18	897	31	0.79	1.09	6.6	1.3	2.99			
19	810	31	1.14	1.57	6.5	0.9	3.03			
20	787	21	0.91	1.22	6.5	1.3	3.07			
21	1,089	42	1.01	1.42	6.5	1.3	2.96			
22	1,450	44	0.87	1.14	6.6	1.3	3.13			
23	1,183	36	0.83	1.06	6.5	1.3	2.99			
24	918	33	1.51	2.14	6.5	1.0	3.24			
25	1,104	42	0.77	1.78	6.5	1.2	3.30			
26	850	25	0.86	1.09	6.5	1.1	3.30			
27	1,061	37	0.83	1.12	6.6	1.1	3.30			
28	1,284	39	0.86	1.12	6.5	1.4	2.97			
29	784	29	0.64	0.89	6.5	1.4	3.01			
30	879	37	0.74	1.04	6.5	1.4	2.97			
31	906	19	0.90	1.27	6.5	1.3	3.04			
TOTAL	28053	944								
MAX	1855	63	1.61	2.20	6.6	1.6	3.30			
MIN	306	9	0.64	0.89	6.4	0.9	2.75			
AVG	905	30	1.02	1.48	6.5	1.3	3.06			
PREPARED BY <i>Bradley S Day (American Water)</i>					DATE <i>1/31/2019</i>		APPROVED BY <i>Bryan M. Raisor</i>		DATE <i>1/31/2019</i>	

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)