

FACILITIES ENGINEERING OPERATING LOG								INSTALLATION : FORT POLK, LA	MONTH	YEAR
(Water - General)								FORT POLK SOUTH WATER (2902) PWS # 1115065	Jul	2019
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE		REMARKS	WELL NO.
			FREE	TOTAL						
1	0	0	1.12	1.30	6.4	0.9	3.44		7	0
2	2.045	64	1.08	1.24	6.5	0.9	3.26		8	9.957
3	0	0	0.91	1.13	6.4	0.9	3.48		9	6.628
4	1.928	59	1.04	1.23	6.4	1.0	2.83		11	6.261
5	0	0	0.78	1.10	6.4	0.9	3.62		12	10.126
6	0	0	1.02	1.25	6.5	1.1	3.22			
7	2.010	65	0.96	1.11	6.5	1.0	3.72		Grand Total	32.972
8	0	0	1.03	1.25	6.4	1.1	3.08			
9	2.056	64	0.94	1.09	6.4	1.0	3.46			
10	0	0	1.00	1.24	6.5	1.0	3.16			
11	2.166	71	0.85	1.09	6.5	1.0	3.44			
12	1.767	55	0.71	1.12	6.5	1.0	3.27			
13	1.109	34	1.07	1.22	6.4	0.9	3.34			
14	666	20	0.97	1.09	6.5	0.9	3.48			
15	0	0	0.95	1.22	6.5	1.0	3.18			
16	2.258	71	0.98	1.13	6.5	1.0	3.43			
17	0	29	0.96	1.14	6.4	0.9	3.16			
18	2.194	41	1.17	1.44	6.4	0.9	3.26			
19	1.848	59	1.08	1.31	6.4	0.9	3.31			
20	0	0	0.80	1.26	6.4	1.0	3.16			
21	2.000	91	1.76	1.94	6.4	1.3	3.76			
22	1.033	26	1.28	1.73	6.5	1.1	3.75			
23	0	0	1.02	1.50	6.3	1.1	3.20			
24	1.900	59	1.11	1.36	6.5	1.1	3.44			
25	0	0	1.21	1.41	6.4	1.0	3.09			
26	1.990	65	1.15	1.32	6.5	1.0	3.39			
27	1.964	64	1.23	1.56	6.4	0.9	3.12			
28	0	0	1.12	1.27	6.4	0.9	3.49			
29	2.100	68	1.31	1.54	6.4	0.9	2.76			
30	0	0	1.00	1.36	6.4	1.0	3.49			
31	1.618	60	1.25	1.47	6.4	1.0	3.19			

TOTAL	32652	1065					
MAX	2258	91	1.76	1.94	6.5	1.3	3.76
MIN	0	0	0.71	1.09	6.3	0.9	2.76
AVG	1053	34	1.06	1.30	6.4	1.0	3.32

PREPARED BY <i>Bradley S Day (American Water)</i>	DATE 7/31/2019	APPROVED BY <i>Bryan M. Raisor</i>	DATE 7/31/2019
--	-------------------	---------------------------------------	-------------------

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)