

FACILITIES ENGINEERING OPERATING LOG						INSTALLATION : FORT POLK, LA			MONTH	YEAR
(Water - General)						FORT POLK SOUTH WATER (2902) PWS # 1115065			Jun	2020
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
		FREE	TOTAL							
1	1,954	73	1.42	1.39	6.5	0.8	2.54	7	6,452	
2	0	0	1.40	1.65	6.5	0.9	2.91	8	6,646	
3	1,989	63	1.46	1.77	6.5	1.1	2.66	9	5,403	
4	0	0	1.44	1.62	6.4	1.0	2.76	11	5,190	
5	1,020	77	1.49	1.72	6.5	1.1	2.64	12	7,958	
6	0	0	1.38	1.62	6.5	1.1	2.90			
7	0	0	1.39	1.66	6.5	1.0	2.66			
8	2,020	73	1.76	1.56	6.5	1.0	2.86			
9	1,855	67	1.38	1.64	6.5	0.8	2.69			
10	0	0	1.39	1.40	6.5	0.8	2.91			
11	2,317	85	1.63	1.87	6.4	0.8	2.69			
12	0	0	1.37	1.56	6.5	0.8	2.82			
13	1,853	72	1.50	1.89	6.4	0.9	2.59			
14	0	0	1.33	1.62	6.5	0.8	2.90			
15	2,266	76	1.55	1.80	6.5	0.9	2.80			
16	0	0	1.38	1.62	6.5	0.9	2.85			
17	2,148	81	1.38	1.77	6.5	0.8	2.40			
18	0	0	1.35	1.63	6.5	0.9	2.84			
19	2,399	79	1.40	1.75	6.5	0.9	2.73			
20	0	0	1.78	1.63	6.5	0.7	2.87			
21	2,157	85	1.48	1.82	6.5	0.7	2.76			
22	0	0	1.32	1.62	6.5	0.9	2.92			
23	2,318	85	1.64	2.01	6.5	0.9	2.76			
24	0	0	1.40	1.54	6.5	0.9	2.92			
25	2,258	95	1.82	2.23	6.5	1.2	3.07			
26	0	0	1.49	1.76	6.5	0.9	3.14			
27	2,411	88	1.68	2.06	6.5	1.1	3.19			
28	0	0	1.62	1.86	6.5	0.9	3.27			
29	2,114	77	1.55	1.86	6.4	0.9	3.24			
30	0	0	1.52	1.75	6.5	1.1	3.26			
Grand Total										
31,649										
5,403 5,190 7,958										
TOTAL	32088	1171								
MAX	2411	95	1.82	2.23	6.5	1.2	3.27			
MIN	0	0	1.22	1.39	6.4	0.7	2.26			
AVG	1070	39	1.45	1.72	6.5	0.9	2.84			
PREPARED BY Bradley S Day (American Water)						DATE 6/30/2020	APPROVED BY Bradley Day	DATE 6/30/2020		

FP FORM **4141**
1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)