

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
<i>(Water - General)</i>					FORT POLK SOUTH WATER (2902) PWS # 1115065					
For use of this form, see AR 420-46; the proponent								Mar	2020	
agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	2,369	77	1.32	1.59	6.6	0.7	2.87		7	6,406
2	0	0	1.23	1.44	6.4	1.0	2.80		8	7,575
3	2,243	77	1.17	1.36	6.5	0.8	2.74		9	5,209
4	1,238	65	1.26	1.38	6.5	0.8	2.81		11	5,056
5	0	28	1.21	1.37	6.5	0.8	2.84		12	7,735
6	2,058	67	1.36	1.52	6.4	0.8	2.83			
7	0	0	1.23	1.36	6.5	1.0	2.89		Grand Total	31,981
8	2,176	64	1.24	1.32	6.5	0.9	2.69			
9	0	0	1.26	1.31	6.6	0.9	3.05			
10	2,288	77	0.99	1.25	6.5	0.8	2.57			
11	0	0	1.06	1.10	6.5	0.8	2.79			
12	0	0	1.06	1.22	6.6	0.8	3.02			
13	2,343	73	1.17	1.32	6.5	0.7	2.64			
14	0	0	1.07	1.19	6.5	0.9	2.76			
15	0	0	1.16	1.45	6.5	0.8	2.65			
16	2,391	82	1.15	1.27	6.4	0.9	2.74			
17	0	0	1.31	1.38	6.5	0.7	2.61			
18	2,404	81	1.38	1.59	6.5	0.7	2.00			
19	0	0	1.22	1.34	6.5	0.8	2.82			
20	2,046	72	1.53	1.63	6.5	0.7	2.64			
21	836	31	1.49	1.60	6.5	0.7	2.62			
22	0	0	1.30	1.46	6.6	0.8	2.78			
23	2,039	68	1.31	1.80	6.4	0.8	2.69			
24	0	0	1.31	1.48	6.4	0.8	2.84			
25	1,988	71	1.42	1.69	6.4	0.7	2.59			
26	0	0	1.37	1.60	6.4	0.8	2.73			
27	1,848	65	1.36	1.72	6.4	0.8	2.63			
28	0	0	1.37	1.57	6.5	0.7	2.69			
29	2,219	76	1.39	1.65	6.5	0.7	2.68			
30	0	0	1.38	1.57	6.5	0.7	2.74			
31	0	0	1.47	1.76	6.5	0.7	2.68			
TOTAL	30486	1074								
MAX	2404	82	1.53	1.80	6.6	1.0	3.05			
MIN	0	0	0.99	1.10	6.4	0.7	2.00			
AVG	983	35	1.28	1.46	6.5	0.8	2.72			
PREPARED BY <i>Bradley S Day (American Water)</i>					DATE <i>3/31/2020</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>3/31/2020</i>	

5.209 5.056 7.735

FP FORM
1 JULY 73 **4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)