

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK SOUTH WATER (2902) PWS # 1115065			Nov	2019	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	1.256	41	1.20	1.45	6.5	0.8	2.66	7	7.112	
2	0	0	1.08	1.26	6.5	0.9	2.73	8	6.988	
3	2.105	65	1.19	1.39	6.5	0.7	2.63	9	5.183	
4	0	0	1.13	1.30	6.5	0.8	2.80	11	4.797	
5	2.073	65	1.15	1.37	6.4	0.7	2.72	12	7.597	
6	0	0	1.18	1.28	6.5	0.8	2.63			
7	2.075	64	1.12	1.27	6.5	0.8	2.68	Grand Total	31.677	
8	0	0	1.11	1.18	6.5	0.8	2.81			
9	2.025	62	0.87	1.21	6.5	0.7	2.54			
10	0	0	1.01	1.23	6.5	0.7	2.64			
11	2.966	87	1.03	1.24	6.5	0.9	2.80			
12	1.089	36	0.93	1.26	6.5	0.9	2.70			
13	408	11	1.04	1.27	6.6	1.0	2.63			
14	773	25	1.15	1.34	6.5	0.9	2.65			
15	0	0	1.07	1.18	6.6	0.8	2.83			
16	1.900	66	1.28	1.54	6.5	0.8	2.83			
17	900	28	1.21	1.34	6.6	0.9	2.77			
18	1.040	35	1.13	1.32	6.6	0.9	2.69			
19	0	0	1.13	1.44	6.5	0.7	2.34			
20	2.093	66	1.09	1.31	6.5	1.0	2.77			
21	1.956	62	1.18	1.34	6.5	0.9	2.72			
22	0	0	1.09	1.21	6.5	1.1	2.79			
23	1.518	45	1.06	1.27	6.5	0.9	2.80			
24	0	0	1.01	1.22	6.5	0.9	2.78			
25	2.260	73	1.14	1.34	6.5	1.0	2.85			
26	1.399	58	1.90	2.11	6.5	1.0	2.99			
27	1.063	32	1.57	1.75	6.5	1.0	2.98			
28	0	0	1.62	1.80	6.5	0.9	2.94			
29	2.106	66	1.65	1.97	6.5	1.2	3.66			
30	0	0	1.42	1.66	6.5	1.0	3.22			
TOTAL	31005	987								
MAX	2966	87	1.90	2.11	6.6	1.2	3.66			
MIN	0	0	0.87	1.18	6.4	0.7	2.34			
AVG	1034	33	1.19	1.40	6.5	0.9	2.79			
PREPARED BY <i>Bradley S Day (American Water)</i>					DATE <i>11/30/2019</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>11/30/2019</i>	

FP

FORM
1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)