

FACILITIES ENGINEERING OPERATING LOG							INSTALLATION : FORT POLK, LA			MONTH	YEAR
(Water - General)							FORT POLK SOUTH WATER (2902) PWS # 1115065			Oct	2019
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.											
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS					REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE				
			FREE	TOTAL							
1	0	0	0.77	1.11	6.7	1.0	3.25		7	2,469	
2	2,319	77	1.03	1.06	6.4	1.1	2.91		8	9,864	
3	0	0	1.07	1.34	6.4	1.2	3.02		9	6,130	
4	2,145	69	1.07	1.26	6.6	1.0	3.02		11	6,219	
5	0	0	0.99	1.38	6.5	1.2	2.91		12	9,852	
6	2,266	72	1.07	1.21	6.5	1.0	2.91				
7	0	0	1.15	1.33	6.4	1.2	3.03				
8	2,168	69	1.13	1.31	6.4	1.2	3.15				
9	0	0	1.13	1.39	6.5	1.2	3.02				
10	2,084	77	1.04	1.34	6.4	1.1	3.27				
11	0	0	1.18	1.37	6.4	1.1	3.12				
12	2,334	78	1.20	1.43	6.4	1.0	3.21				
13	0	0	1.16	1.37	6.4	1.0	3.12				
14	2,304	79	1.14	1.34	6.4	0.9	3.05				
15	0	0	1.11	1.26	6.5	1.1	2.97				
16	1,998	67	1.15	1.41	6.4	1.2	3.20				
17	0	0	1.20	1.43	6.5	0.9	3.05				
18	2,116	65	1.03	1.23	6.5	0.8	3.16				
19	0	0	1.17	1.41	6.5	0.9	3.05				
20	2,399	81	1.10	1.33	6.5	0.9	3.15				
21	0	0	1.20	1.45	6.5	0.9	3.04				
22	1,916	61	1.07	1.24	6.5	0.9	3.15				
23	0	0	1.32	1.53	6.4	0.9	2.89				
24	2,310	80	1.21	1.41	6.5	1.0	3.06				
25	2,215	53	1.01	1.23	6.5	0.9	2.63				
26	0	0	1.01	1.20	6.5	0.9	2.83				
27	1,856	49	0.87	1.01	6.5	0.9	2.50				
28	0	0	0.99	1.15	6.6	0.9	2.56				
29	1,961	62	1.09	1.22	6.5	0.9	2.51				
30	0	0	1.15	1.35	6.5	0.9	2.42				
31	2,128	65	0.97	1.16	6.5	0.9	2.55				

TOTAL	34519	1104						
MAX	2399	81	1.32	1.53	6.7	1.2	3.27	
MIN	0	0	0.77	1.01	6.4	0.8	2.42	
AVG	1114	36	1.09	1.30	6.5	1.0	2.96	

PREPARED BY <i>Bradley S Day (American Water)</i>	DATE <i>10/31/2019</i>	APPROVED BY <i>Bradley Day</i>	DATE <i>10/31/2019</i>
--	---------------------------	-----------------------------------	---------------------------

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)