

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK NORTH WATER (7216)</b> <b>PWS # 1115064</b>			Apr	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	129	0	1.39	1.48	7.5	0.9	3.59		2	1,773
2	275	0	1.38	1.39	7.5	0.9	3.15		6A	1,228
3	119	22	1.61	1.64	7.5	0.8	2.98		6B	0
4	130	0	1.39	1.55	7.5	0.9	2.98		7	1,324
5	145	0	1.53	1.57	7.5	0.9	3.04			
6	131	17	1.50	1.60	7.5	0.9	2.98			
7	142	0	1.51	1.57	7.5	0.9	3.62			
8	132	0	1.60	1.69	7.5	0.9	3.54			
9	141	0	1.45	1.46	7.5	0.9	3.64			
10	137	22	1.38	1.46	7.5	0.9	3.36			
11	143	0	1.75	1.95	7.5	1.0	3.02			
12	140	0	1.39	1.42	7.5	0.9	3.56			
13	253	18	1.72	1.75	7.2	1.0	2.99			
14	29	0	1.54	1.67	7.3	1.0	3.43			
15	154	0	1.72	1.78	7.2	1.0	2.98			
16	282	19	1.59	1.77	7.2	1.0	3.03			
17	129	15	1.62	1.71	7.3	1.0	3.12			
18	196	0	1.52	1.65	7.4	0.9	3.02			
19	139	0	1.51	1.64	7.5	0.9	3.00			
20	133	16	1.39	1.50	7.5	1.0	3.20			
21	144	0	1.45	1.56	7.1	1.0	3.21			
22	145	0	1.98	2.13	7.0	0.9	3.47			
23	166	18	1.36	1.40	7.0	0.9	3.60			
24	243	11	1.45	1.46	7.2	0.9	3.13			
25	130	0	1.52	1.71	7.4	1.0	3.14			
26	138	0	1.42	1.50	7.5	0.9	2.98			
27	131	0	1.44	1.48	7.3	0.9	3.00			
28	141	21	1.44	1.56	7.4	1.0	3.04			
29	68	0	1.35	1.44	7.3	0.9	3.41			
30	129	0	1.25	1.32	7.3	1.0	3.41			
<b>Grand Total</b>										
4,325										

4.702      4.486      7.093

TOTAL	4514	179					
MAX	282	22	1.98	2.13	7.5	1.0	3.64
MIN	29	0	1.25	1.32	7.0	0.8	2.98
AVG	150	6	1.51	1.59	7.4	0.9	3.22

PREPARED BY	DATE	APPROVED BY	DATE
Noah Belcher (American Water)	4/30/2020	Bradley Day	4/30/2020

**FP**

FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)