

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK NORTH WATER (7216) PWS # 1115064					
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.								Apr	2019	
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	182	15	1.26	1.44	7.4	1.1	3.30	2	2,749	
2	348	16	1.13	1.26	7.4	1.0	2.76	6A	0	
3	212	0	0.84	1.15	7.5	1.2	2.78	6B	1,739	
4	389	26	0.99	1.12	7.4	1.1	2.67	7	1,930	
5	249	10	1.04	1.17	7.5	1.2	2.85			
6	117	0	0.91	1.06	7.4	1.1	3.19			
7	243	0	0.92	1.07	7.4	1.0	2.91	Grand Total	6,418	
8	123	16	0.88	0.93	7.5	1.3	3.30			
9	239	0	0.96	1.13	7.5	1.1	2.82			
10	74	0	0.87	0.90	7.7	1.0	3.30			
11	253	20	0.72	0.83	7.5	0.9	3.15			
12	226	14	0.78	1.00	7.5	1.2	2.81			
13	232	0	1.08	1.24	7.5	1.2	3.00			
14	178	4	1.24	1.36	7.5	1.3	3.30			
15	78	0	0.91	0.98	7.5	1.5	3.22			
16	160	21	1.23	1.31	7.5	1.1	3.17			
17	405	20	1.08	1.19	7.3	1.3	3.13			
18	133	0	1.00	1.14	7.6	1.1	3.30			
19	263	0	1.20	1.39	7.5	1.1	3.05			
20	134	17	1.02	1.16	7.4	1.0	3.30			
21	129	0	1.32	1.39	7.5	1.2	3.13			
22	276	18	1.01	1.31	7.6	1.2	3.07			
23	297	24	1.37	1.38	7.4	0.8	3.03			
24	250	0	1.55	1.71	7.5	1.3	3.04			
25	182	0	1.22	1.36	7.4	1.2	3.27			
26	312	20	1.20	1.35	7.4	1.0	3.11			
27	268	0	1.43	1.59	7.4	0.9	3.06			
28	66	0	1.13	1.15	7.4	1.0	3.94			
29	173	17	1.27	1.28	7.4	1.3	3.41			
30	321	0	0.98	1.38	7.5	1.1	3.12			

TOTAL	6512	258							
MAX	405	26	1.55	1.71	7.7	1.5	3.94		
MIN	66	0	0.72	0.83	7.3	0.8	2.67		
AVG	217	9	1.08	1.22	7.5	1.1	3.12		
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>4/30/2019</i>		APPROVED BY <i>Bryan M. Raisor</i>		DATE <i>4/30/2019</i>

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)