

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR
<i>(Water - General)</i>					FORT POLK NORTH WATER (7216) PWS # 1115064			Dec	2019
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.									
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			OTA RESIDUAL CHLORINE		PH	FLUORIDE			
			FREE	TOTAL					
1	144	17	1.41	1.42	7.5	0.8	3.11		
2	0	0	1.46	1.60	7.5	0.7	2.63		
3	281	0	1.39	1.39	7.5	0.9	2.72		
4	237	31	1.41	1.42	7.4	0.8	2.88		
5	247	0	1.47	1.55	7.5	0.8	2.79		
6	230	23	1.66	1.67	7.6	0.8	2.97		
7	237	0	1.62	1.70	7.5	0.8	2.96		
8	238	21	1.81	1.85	7.5	0.8	2.88		
9	267	0	2.00	2.01	7.5	0.7	2.69		
10	0	0	1.93	1.99	7.6	0.7	2.69		
11	245	20	1.70	1.75	7.6	0.8	3.10		
12	252	0	1.64	1.73	7.6	0.9	2.71		
13	264	23	1.75	1.76	7.6	0.8	2.89		
14	0	0	1.55	1.59	7.7	0.8	2.76		
15	249	0	1.55	1.58	7.7	0.8	2.70		
16	0	0	1.52	1.50	7.6	0.8	3.15		
17	233	19	1.45	1.47	7.7	0.8	2.82		
18	281	0	1.49	1.63	7.7	0.8	2.32		
19	0	0	1.18	1.43	7.7	0.9	2.97		
20	225	22	1.42	1.43	7.7	0.9	3.12		
21	0	0	1.38	1.39	7.6	0.9	2.86		
22	264	0	1.34	1.42	7.6	0.9	2.82		
23	149	17	1.33	1.42	7.7	0.9	2.98		
24	0	0	1.43	1.44	7.7	0.8	2.96		
25	300	0	1.43	1.44	7.5	0.7	2.87		
26	242	24	1.50	1.55	7.6	0.8	3.09		
27	0	0	1.40	1.41	7.6	0.8	3.27		
28	259	0	1.47	1.51	7.5	0.8	3.06		
29	239	0	1.78	1.81	7.5	0.8	2.84		
30	0	22	1.52	1.55	7.6	0.9	2.92		
31	107	0	1.75	1.85	7.6	0.8	2.83		
<hr/>									
TOTAL	5190	239							
MAX	300	31	2.00	2.01	7.7	0.9	3.27		
MIN	0	0	1.18	1.39	7.4	0.7	2.32		
AVG	167	8	1.54	1.59	7.6	0.8	2.88		
<hr/>									
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>12/31/2019</i>		APPROVED BY <i>Bradley Day</i>		DATE <i>12/31/2019</i>

5.155 4.843 7.540

FP

FORM
1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)