

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA				MONTH	YEAR
(Water - General)					FORT POLK NORTH WATER (7216) PWS # 1115064				Feb	2019
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	140	5	1.09	1.24	7.5	1.1	2.90		2	2,535
2	0	0	1.08	1.20	7.4	1.1	3.03		6A	0
3	287	0	1.19	1.29	7.5	1.1	2.90		6B	1,586
4	142	17	1.10	1.21	7.5	1.2	2.93		7	1,753
5	282	18	1.21	1.63	7.5	1.1	3.30			
6	271	16	1.24	1.36	7.5	1.2	2.84			
7	224	0	1.35	1.47	7.5	1.3	3.08		Grand Total	5,874
8	218	12	1.50	1.61	7.6	1.2	3.22			
9	264	0	1.42	1.52	7.6	1.1	2.83			
10	138	18	1.15	1.28	7.6	1.1	3.30			
11	284	12	1.29	1.37	7.4	1.2	3.30			
12	127	0	1.29	1.46	7.4	1.0	2.86			
13	275	18	1.22	1.52	7.5	1.0	3.00			
14	141	0	1.16	1.35	7.5	1.0	3.30			
15	279	16	1.22	1.32	7.5	1.3	2.99			
16	265	0	1.29	1.54	7.4	1.1	2.88			
17	136	0	1.19	1.28	7.4	1.1	3.22			
18	265	22	1.16	1.39	7.4	1.1	2.74			
19	146	0	1.23	1.24	7.4	1.1	3.17			
20	185	16	1.03	1.22	7.4	0.9	3.30			
21	283	0	1.11	1.36	7.4	1.0	3.30			
22	247	23	1.15	1.21	7.4	1.2	2.90			
23	279	0	1.10	1.15	7.4	1.2	2.88			
24	277	17	1.15	1.27	7.4	1.0	3.10			
25	225	15	0.96	1.19	7.6	1.2	2.88			
26	298	0	1.22	1.34	7.5	1.2	2.92			
27	283	17	1.47	1.63	7.4	1.2	2.84			
28	139	0	0.92	1.09	7.4	1.3	3.07			

TOTAL	6100	242								
MAX	298	23	1.50	1.63	7.6	1.3	3.30			
MIN	0	0	0.92	1.09	7.4	0.9	2.74			
AVG	218	9	1.20	1.35	7.5	1.1	3.04			
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE 2/28/2019		APPROVED BY Bryan M. Raisor		DATE 2/28/2019	

FORM
4141
1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)