

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					<b>FORT POLK NORTH WATER (7216)</b> <b>PWS # 1115064</b>			Jan	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	193	0	1.48	1.58	7.5	0.8	2.96		2	2,833
2	254	22	1.84	1.99	7.5	0.8	2.94		6A	1,926
3	0	0	1.89	2.18	7.5	0.8	3.14		6B	0
4	248	0	1.55	1.51	7.6	0.8	2.92		7	2,066
5	0	0	1.53	1.59	7.5	0.8	2.91			
6	266	21	1.45	1.48	7.5	0.8	3.06			
7	256	0	1.53	1.54	7.5	0.8	2.91		Grand Total	6,825
8	0	0	1.48	1.47	7.5	0.9	2.91			
9	265	21	1.49	1.45	7.6	0.8	3.11			
10	392	19	1.63	1.58	7.5	0.7	2.82			
11	212	0	1.54	1.59	7.3	0.8	2.88			
12	608	20	1.71	2.08	7.4	0.8	3.04			
13	0	0	1.48	1.48	7.5	0.8	3.03			
14	243	24	1.47	1.49	7.6	0.8	2.93			
15	236	0	1.49	1.52	7.4	0.8	2.96			
16	174	18	1.42	1.47	7.5	0.8	2.89			
17	253	9	1.57	1.57	7.5	0.8	2.79			
18	185	0	1.61	1.75	7.3	0.8	2.80			
19	56	0	1.29	1.57	7.4	0.9	2.75			
20	194	17	1.54	1.56	7.5	0.9	2.94			
21	242	0	1.48	1.55	7.5	0.9	2.89			
22	298	0	1.60	1.72	7.5	0.9	2.51			
23	0	20	1.35	1.56	7.4	1.0	2.51			
24	255	0	1.45	1.54	7.6	1.0	2.60			
25	260	24	1.50	1.61	7.6	0.9	2.56			
26	0	0	1.48	1.54	7.5	1.0	2.45			
27	260	0	1.38	1.66	7.4	0.9	2.95			
28	0	22	1.76	1.80	7.4	0.9	2.62			
29	294	0	1.42	1.61	7.5	1.0	2.33			
30	310	25	1.49	1.57	7.4	1.0	2.79			
31	467	23	1.55	1.69	7.4	0.9	2.69			

TOTAL	6421	285					
MAX	608	25	1.89	2.18	7.6	1.0	3.14
MIN	0	0	1.29	1.45	7.3	0.7	2.33
AVG	207	9	1.53	1.62	7.5	0.9	2.83

PREPARED BY	DATE	APPROVED BY	DATE
<i>Noah Belcher (American Water)</i>	<i>1/31/2020</i>	<i>Bradley Day</i>	<i>1/31/2020</i>

**FP**

FORM

**4141**

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)