

FACILITIES ENGINEERING OPERATING LOG								INSTALLATION : FORT POLK, LA		MONTH	YEAR	
(Water - General)								FORT POLK NORTH WATER (7216) PWS # 1115064		Jul	2019	
For use of this form, see AR 420-46: the proponent agency is the Office of the Chief of Engineers.												
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			OTA RESIDUAL CHLORINE		FREE	TOTAL						
1	158	0	1.48	1.60	7.4	1.1	2.73			2	3.080	
2	159	20	1.44	1.62	7.4	1.2	3.01			6A	0	
3	160	0	0.94	1.59	7.4	0.9	2.77			6B	1.753	
4	134	0	1.72	1.84	7.5	1.1	3.64			7	1.914	
5	167	23	1.64	1.83	7.5	0.9	2.90					
6	0	0	1.30	1.53	7.5	1.1	3.10					
7	160	0	1.28	1.33	7.5	0.9	3.08			Grand Total	6.747	
8	164	0	1.86	2.02	7.3	1.0	3.28					
9	230	26	1.29	1.37	7.3	1.0	3.11					
10	168	0	1.37	1.47	7.3	1.0	2.97					
11	178	0	1.19	1.41	7.4	1.1	2.95					
12	300	30	1.53	1.78	7.5	1.1	2.60					
13	165	0	1.50	1.63	7.5	1.0	2.67					
14	100	0	1.26	1.36	7.5	1.0	2.90					
15	163	20	1.19	1.36	7.4	1.0	2.98					
16	156	0	1.50	1.73	7.4	1.1	2.62					
17	296	22	1.30	1.36	7.3	1.2	3.00					
18	324	0	1.11	1.49	7.4	1.2	2.91					
19	163	23	1.32	1.40	7.4	1.1	2.98					
20	324	0	1.46	1.63	7.4	1.0	2.83					
21	260	30	1.32	1.39	7.3	1.1	3.02					
22	0	0	0.87	1.24	7.4	1.0	3.09					
23	283	0	1.27	1.37	7.3	1.0	3.03					
24	195	24	1.32	1.44	7.5	1.0	3.03					
25	229	0	1.43	1.54	7.3	1.0	2.88					
26	242	23	1.42	1.56	7.3	1.1	2.84					
27	251	0	1.48	1.69	7.3	1.0	2.40					
28	280	27	1.46	1.67	7.2	1.0	2.32					
29	253	0	1.28	1.50	7.5	1.0	2.63					
30	310	28	1.47	1.53	7.5	0.9	2.32					
31	270	0	1.45	1.65	7.5	1.0	2.26					
TOTAL	6242	296										
MAX	324	30	1.86	2.02	7.5	1.2	3.64					
MIN	0	0	0.87	1.24	7.2	0.9	2.26					
AVG	201	10	1.37	1.55	7.4	1.0	2.87					
PREPARED BY <i>Noah Belcher (American Water)</i>								DATE 7/31/2019	APPROVED BY <i>Bryan M. Raisor</i>	DATE 7/31/2019		

FP

FORM
1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)