

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK NORTH WATER (7216) PWS # 1115064			Mar	2020	
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	152	0	1.53	1.72	7.5	0.8	3.32		2	2,009
2	163	23	1.43	1.53	7.5	0.8	2.85		6A	1,328
3	157	0	1.18	1.63	7.4	0.8	2.90		6B	0
4	152	0	1.37	1.60	7.5	0.8	2.96		7	1,427
5	158	20	1.47	1.63	7.5	1.0	2.88			
6	268	12	1.49	1.75	7.4	1.1	2.74			
7	164	0	1.52	1.70	7.3	1.0	2.76			
8	0	0	1.45	1.68	7.4	1.0	3.00			
9	156	0	1.47	1.58	7.5	1.0	3.00			
10	169	20	1.46	1.51	7.5	1.0	3.11			
11	163	0	1.43	1.55	7.5	1.0	3.13			
12	114	0	1.65	1.60	7.5	0.9	3.12			
13	118	18	1.37	1.38	7.5	1.0	3.22			
14	131	0	1.19	1.37	7.5	1.0	2.95			
15	126	0	1.08	1.41	7.4	1.0	3.30			
16	147	18	1.53	1.64	7.6	1.0	3.54			
17	126	0	1.23	1.30	7.5	0.9	3.22			
18	176	0	1.39	1.46	7.5	1.0	3.39			
19	134	20	1.61	1.56	7.5	0.9	2.94			
20	145	0	1.39	1.46	7.4	0.9	3.27			
21	0	0	1.35	1.38	7.4	1.0	3.40			
22	245	15	1.57	1.67	7.5	0.9	2.56			
23	257	0	1.42	1.52	7.5	0.9	2.57			
24	162	18	1.47	1.48	7.5	0.9	3.08			
25	150	0	1.52	1.57	7.5	0.9	3.13			
26	145	0	2.02	2.08	7.5	0.9	3.57			
27	124	17	1.46	1.53	7.5	0.9	3.13			
28	153	0	1.85	1.95	7.5	0.9	3.36			
29	0	0	1.29	1.33	7.5	0.9	3.55			
30	125	0	1.43	1.43	7.4	0.9	3.28			
31	142	18	1.33	1.33	7.5	0.8	3.32			
Grand Total										
										4,764

TOTAL	4422	199						
MAX	268	23	2.02	2.08	7.6	1.1	3.57	
MIN	0	0	1.08	1.30	7.3	0.8	2.56	
AVG	143	6	1.45	1.56	7.5	0.9	3.11	

PREPARED BY	DATE	APPROVED BY	DATE
<i>Noah Belcher (American Water)</i>	<i>3/31/2020</i>	<i>Bradley Day</i>	<i>3/31/2020</i>

5.209 5.056 7.735

FP

FORM
1 JULY 73

4141

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)