

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
(Water - General)					FORT POLK NORTH WATER (7216) PWS # 1115064					
For use of this form, see AR 420-46; the proponent										
agency is the Office of the Chief of Engineers.								Mar	2019	
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	339	24	1.16	1.34	7.5	1.1	2.67		2	2,877
2	143	0	1.05	1.14	7.5	1.1	2.89		6A	0
3	134	0	0.98	1.11	7.4	1.2	3.08		6B	1,788
4	282	16	1.09	1.16	7.4	1.1	2.98		7	1,995
5	285	19	1.11	1.25	7.4	1.0	2.86			
6	294	0	1.22	1.40	7.3	1.0	2.76			
7	296	18	1.20	1.35	7.4	1.2	2.75		Grand Total	6,660
8	280	21	1.23	1.39	7.6	1.2	2.71			
9	261	0	1.08	1.28	7.5	1.3	2.88			
10	257	21	1.22	1.42	7.5	1.3	2.65			
11	123	0	1.15	1.17	7.3	1.2	3.12			
12	284	16	0.95	1.02	7.4	1.2	2.91			
13	113	0	0.97	1.34	7.3	1.1	3.30			
14	270	10	1.20	1.36	7.3	1.2	2.77			
15	188	12	1.01	1.30	7.5	1.3	2.94			
16	131	0	0.85	1.24	7.4	1.1	2.98			
17	136	0	1.15	1.18	7.4	1.2	3.30			
18	146	18	1.05	1.16	7.4	1.2	3.01			
19	301	0	1.19	1.31	7.3	1.2	2.80			
20	130	18	1.07	1.20	7.4	1.2	3.01			
21	149	0	1.06	1.21	7.4	1.2	2.98			
22	277	18	1.20	1.31	7.4	1.2	2.86			
23	281	0	1.40	1.51	7.4	1.2	2.68			
24	132	17	1.16	1.33	7.5	1.1	3.01			
25	282	0	1.22	1.33	7.6	1.2	3.24			
26	282	24	1.38	1.52	7.4	1.2	3.04			
27	295	20	1.28	1.48	7.4	0.9	2.80			
28	184	0	1.48	1.60	7.4	0.9	2.73			
29	237	17	1.46	1.66	7.4	1.2	2.81			
30	288	2	1.51	1.64	7.4	1.4	2.75			
31	183	0	1.48	1.67	7.3	1.2	2.75			

TOTAL	6983	291								
MAX	339	24	1.51	1.67	7.6	1.4	3.30			
MIN	113	0	0.85	1.02	7.3	0.9	2.65			
AVG	225	9	1.18	1.33	7.4	1.2	2.90			
PREPARED BY <i>Noah Belcher (American Water)</i>					DATE <i>3/31/2019</i>		APPROVED BY <i>Bryan M. Raisor</i>		DATE <i>3/31/2019</i>	

FP

FORM

4141

1 JULY 73

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)