

FACILITIES ENGINEERING OPERATING LOG					INSTALLATION : FORT POLK, LA			MONTH	YEAR	
<i>(Water - General)</i>					<b>FORT POLK NORTH WATER (7216)</b> <b>PWS # 1115064</b>					
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.								Nov	2019	
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	CHEMICAL ANALYSIS				REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL	
			OTA RESIDUAL CHLORINE		PH	FLUORIDE				PHOSPHATE
			FREE	TOTAL						
1	130	19	1.27	1.50	7.4	0.8	2.99		2	2,449
2	234	0	1.44	1.63	7.4	0.9	2.84		6A	30
3	259	23	1.38	1.53	7.4	0.9	2.90		6B	1,519
4	228	0	1.46	1.53	7.5	0.9	2.99		7	1,735
5	179	20	1.33	1.49	7.5	0.9	3.07			
6	249	0	1.45	1.59	7.5	1.0	3.25			
7	247	23	1.37	1.64	7.5	1.3	3.34		Grand Total	5,733
8	345	16	1.73	2.05	7.4	1.2	2.85			
9	0	0	1.42	1.54	7.4	0.8	2.87			
10	250	0	1.44	1.55	7.5	0.8	2.65			
11	150	18	1.54	1.62	7.6	0.8	2.91			
12	236	10	1.61	1.65	7.5	0.8	2.93			
13	0	0	1.80	1.97	7.6	0.8	2.83			
14	283	15	1.57	1.65	7.4	0.9	2.90			
15	247	25	1.84	1.94	7.5	0.8	2.83			
16	165	0	1.53	1.63	7.7	0.8	2.69			
17	258	0	1.58	1.62	7.7	0.8	3.24			
18	246	23	1.67	1.66	7.7	0.8	2.78			
19	271	0	1.64	1.78	7.6	0.8	2.56			
20	136	16	1.50	1.53	7.6	0.7	2.59			
21	246	0	1.53	1.59	7.5	0.7	2.71			
22	239	23	1.70	1.74	7.6	0.7	2.73			
23	0	0	1.45	1.56	7.6	0.8	3.01			
24	241	0	1.57	1.63	7.6	0.8	2.79			
25	0	0	1.46	1.49	7.5	0.9	2.88			
26	270	21	1.46	1.47	7.5	0.8	2.87			
27	210	0	1.47	1.48	7.5	0.8	2.90			
28	238	0	1.61	1.64	7.5	0.7	2.61			
29	0	19	1.81	1.88	7.5	0.7	3.00			
30	246	0	1.33	1.40	7.5	0.7	2.98			

TOTAL	5803	271					
MAX	345	25	1.84	2.05	7.7	1.3	3.34
MIN	0	0	1.27	1.40	7.4	0.7	2.56
AVG	193	9	1.53	1.63	7.5	0.8	2.88

PREPARED BY	DATE	APPROVED BY	DATE
Noah Belcher (American Water)	11/30/2019	Bradley Day	11/30/2019

**FP**

FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)