

FACILITIES ENGINEERING OPERATING LOG							INSTALLATION : FORT POLK, LA		MONTH	YEAR
(Water - General)							FORT POLK SOUTH WATER (2902) PWS # 1115065		Jun	2019
For use of this form, see AR 420-46; the proponent agency is the Office of the Chief of Engineers.										
DATE	DISTRIBUTION WATER 1000 GAL	CHLORINE POUNDS USED	OTA RESIDUAL CHLORINE		PH	FLUORIDE	PHOSPHATE	REMARKS	WELL NO.	TOTAL MONTH PRODUCTION 1000 GAL
			FREE	TOTAL						
1	0	0	0.97	1.13	6.4	1.0	3.41		7	0
2	1.520	49	1.16	1.44	6.4	1.1	3.03		8	9.012
3	0	0	0.91	1.19	6.4	1.0	3.40		9	6.229
4	2.044	62	1.10	1.36	6.5	0.9	2.89		11	6.253
5	0	0	0.94	1.22	6.4	0.9	3.38		12	9.105
6	1.912	60	1.15	1.23	6.4	0.9	3.11			
7	0	0	0.97	1.07	6.4	0.9	3.50		Grand Total	30.599
8	2.074	66	1.06	1.30	6.4	1.0	3.22			
9	0	0	0.99	1.04	6.4	1.0	4.08			
10	2.167	67	1.04	1.25	6.4	1.0	3.18			
11	0	0	0.97	1.08	6.5	0.9	3.56			
12	2.379	67	1.12	1.54	6.5	0.9	3.14			
13	0	0	1.00	1.09	6.5	1.0	3.33			
14	1.895	60	1.20	1.37	6.5	1.0	3.54			
15	0	0	0.96	1.12	6.4	0.9	3.50			
16	0	0	1.26	1.42	6.5	1.0	3.18			
17	2.466	81	1.01	1.18	6.5	0.9	3.46			
18	0	0	1.20	1.43	6.5	0.9	3.25			
19	2.228	77	0.91	1.20	6.4	0.9	3.51			
20	0	0	1.17	1.31	6.5	1.0	3.19			
21	2.525	72	1.18	1.41	6.4	1.0	3.24			
22	0	0	1.20	1.39	6.4	0.9	3.18			
23	2.686	78	0.90	1.35	6.3	0.9	3.21			
24	0	0	1.09	1.30	6.4	1.0	3.56			
25	0	0	1.17	1.41	6.4	1.0	3.01			
26	2.294	73	1.07	1.27	6.4	1.0	3.50			
27	0	0	1.06	1.21	6.4	1.0	3.48			
28	2.400	79	1.24	1.47	6.4	0.9	3.17			
29	0	0	1.20	1.56	6.4	0.9	2.95			
30	2.242	72	1.20	1.41	6.4	0.8	3.34			

TOTAL	30832	963					
MAX	2686	81	1.26	1.56	6.5	1.1	4.08
MIN	0	0	0.90	1.04	6.3	0.8	2.89
AVG	1028	32	1.08	1.29	6.4	1.0	3.32

PREPARED BY	DATE	APPROVED BY	DATE
Bradley S Day (American Water)	6/30/2019	Bryan M. Raisor	6/30/2019

**FP**

FORM  
1 JULY 73

**4141**

REPLACES DA FORM 5-58, 1 MAY 63 WHICH WILL BE USED  
EDITED FROM DA 141 ON 1 SEPT 99 (FORT POLK SPECIFIC)