



BLOWOFF ASSEMBLY

NOTES:

1. POLYETHYLENE ENCASING ON ALL D.I. PIPE.
2. BLOWOFF PIPE SHALL BE SIZED TO PROVIDE A MINIMUM BLOWOFF VELOCITY OF 2 FT/SEC OR PER THE STATE REQUIREMENTS.

REVISIONS
6/13 - MSG EDITS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP CIVIL BLOWOFF ASSEMBLY DETAIL	
AMERICAN WATER MILITARY SERVICES GROUP MT LAUREL, NJ 08054	
AMERICAN WATER M.S.G. 330 FELLOWSHIP ROAD MT LAUREL, NJ 08054	AMERICAN WATER.
DRAWN BY PDK PROJECT ENG'R PDK APPROVED	DATE 06-03-2013 PROJECT N/A USE DIMENSIONS ONLY SCALE N.T.S.
USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES	MSG-W-15

FINAL

MSG-W-15