



## SHALLOW BURY AIR RELEASE VALVE ASSEMBLY DETAIL

**NOTES:**

1. VALVE VAULTS MUST BE PROVIDED WITH PROPER DRAINAGE AND NOT SUBJECT TO HIGH GROUNDWATER LEVELS, SURFACE FLOODING AND PONDING, OR CONTAMINANT OR POLLUTANT SPILLS.
2. VALVE VAULT SHALL BE VENTED TO PROVIDE SUFFICIENT AIR FLOW TO ALLOW PROPER OPERATION OF THE AIR VALVE.
3. THE OPEN END OF THE RELIEF PIPE SHALL BE EXTENDED TO THE TOP OF THE CHAMBER AND PROVIDED WITH A SCREENED, DOWNWARD FACING ELBOW.
4. THIS TAPPING DETAIL IS FOR D.I. AND PVC PIPE ONLY.

REVISIONS
6/13 - MSG EDITS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP  
CIVIL  
SHALLOW BURY AIR RELEASE  
VALVE ASSEMBLY DETAIL

AMERICAN WATER MILITARY SERVICES GROUP  
CAMDEN, NJ 08102

AMERICAN WATER M.S.G.  
1 WATER STREET  
CAMDEN, NJ 08102



DRAWN BY J. ABRERA  
PROJECT ENG'R J. DERUSSO  
APPROVED

DATE 05-03-2010  
PROJECT N/A

USE DIMENSIONS ONLY  
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY  
FOR CONSTRUCTION PURPOSES

MSG-W-02-VA

FINAL

MSG-W-02