



BLOWOFF ASSEMBLY

NOTES:

1. POLYETHYLENE ENCASING ON ALL D.I. PIPE.
2. BLOWOFF PIPE SHALL BE SIZED TO PROVIDE A MINIMUM BLOWOFF VELOCITY OF 2 FT/SEC OR PER THE STATE REQUIREMENTS.

REVISIONS
6/13 - MSG EDITS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP
CIVIL
BLOWOFF ASSEMBLY
DETAIL

AMERICAN WATER MILITARY SERVICES GROUP
CAMDEN, NJ 08102

AMERICAN WATER M.S.G.
1 WATER STREET
CAMDEN, NJ 08102



DRAWN BY PDK
PROJECT ENG'R PDK
APPROVED

DATE 06-03-2013
PROJECT N/A

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

MSG-W-15