



2017 WATER QUALITY REPORT

Bangor

Public Water Supply ID# PA3480038



Este informe contiene información importante acerca de su agua potable. Haga que traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you if needed.)

A Message from the Pennsylvania American Water President

Dear Valued Customer:

On behalf of all Pennsylvania American Water employees, I am pleased to report very good news about the quality of your drinking water. This annual Water Quality Report provides the results of local water testing between January and December 2017, and as you will see, we continue to supply your community with water that meets or surpasses all regulatory standards.

Water service from Pennsylvania American Water is an exceptional value. To deliver quality water to your tap, we employ a great deal of science, expertise, technology and infrastructure to bring water from the source, treat it and ensure it is clean and safe. In addition, our plant operators, water quality experts, engineers and maintenance crews work around the clock to make sure reliable water service is always there when you need it.

Delivering high-quality water service also requires significant investment to replace and upgrade aging pipe, equipment and facilities. **In 2017 alone, we invested nearly \$300 million in system improvements across the Commonwealth.**

Water is essential for public health, fire protection, economic development and our overall quality of life. Every Pennsylvania American Water employee takes this responsibility very seriously and works hard to keep water flowing not only today but for the next generation. Please take the time to read this report and learn more about the source and quality of your drinking water.

Sincerely,

Jeffrey L. McIntyre
President, Pennsylvania American Water



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

Our Mark of Excellence

With a history dating back to 1886, American Water is the largest and most geographically diverse U.S. publicly traded water and wastewater utility company. The company employs more than 6,900 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to an estimated 15 million people in 46 states and Ontario, Canada. American Water provides safe, clean, affordable and reliable water services to our customers to make sure we keep their lives flowing. For more information, visit amwater.com and follow American Water on [Twitter](#), [Facebook](#) and [LinkedIn](#).

Pennsylvania American Water, a subsidiary of American Water, is the largest investor-owned water utility in the state, providing high-quality and reliable water and/or wastewater services to approximately 2.4 million people.

We are once again proud to present our annual water quality report. This edition covers all testing completed from January through December 2017. Over the years, we have dedicated ourselves to producing drinking water that meets or surpasses all state and federal drinking water standards. We continually strive to adopt new and better methods of delivering the best quality drinking water to you. As regulations and drinking water standards become more stringent, it is our commitment to you to ensure compliance with these standards in an expeditious and cost-effective manner, while maintaining our objective of providing quality drinking water at an affordable price. We are pleased to tell you that our compliance with all state and federal drinking water laws remains exemplary. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all our water users.

For more information about this report, or for any questions relating to your drinking water, please feel free to call our Customer Service Department at 1-800-565-7292.

Source Water Information

One surface water source, Lower Handelong Reservoir, and six wells supply the Pennsylvania American Water Company's Bangor service area. Pennsylvania American Water maintains a treatment facility near the Lower Handelong Reservoir capable of processing a maximum of 2.5 million gallons of water per day (MGD). The six wells supply approximately 0.1 MGD to the West Bangor portion of the service area. The water supply is distributed for residential, commercial, and industrial use.

Protecting Your Water Source

The Pennsylvania Department of Environmental Protection (DEP) and Pennsylvania American Water Company completed a draft assessment of the drinking water sources for the Bangor surface water and groundwater supplies in 2004. Although no man-made contaminants were detected, the water sources were considered most vulnerable to the following potential impacts: aboveground storage tanks, auto repair shops, industrial parks, underground petroleum storage tanks and quarries. The final public meeting and report were completed in March of 2005.

A summary of the completed Source Water Assessment will be made available on the DEP website at www.dep.state.pa.us. Additional information may also be obtained by calling the local office of the DEP at (570) 826-2511. Pennsylvania American Water Company encourages you to take an active part in protecting your water supply by participating in local watershed activities as they occur in your area.

Other Water Quality Parameters of Interest

Is there lead in your water?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pennsylvania American Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at:

[U.S. Environmental Protection Agency Web Page on Lead](#)



Does your water contain nitrates?

PAW's normal range of nitrate levels is well below the MCL of 10 ppm. Nitrates enter the water supply from fertilizers used on farms and natural erosion of deposits in the watershed. Levels above 10 ppm are a health risk for infants under six months of age and can cause blue baby syndrome. Check with your physician if you have questions.

How hard is your water?

Hardness is a measure of the concentration of two minerals naturally present in water – calcium and magnesium. High hardness levels cause soap not to foam as easily as it would at lower levels and tends to form scale in household plumbing. Hardness levels averaged 26 ppm or approximately 1.5 grains per gallon and ranged from 18 ppm to 36 ppm, or 1.1 to 2.1 grains per gallon of water. The water is classified as slightly hard.

How much sodium is in your water?

The sodium level averaged 6.1 ppm and ranged from 5 ppm to 7.1 ppm. Although the amount of sodium in drinking water is insignificant compared to the sodium normally consumed in the average diet, it does become a concern to people on low sodium diets recommending less than 20 ppm intake from drinking water. High levels of salt intake may be associated with hypertension in some individuals. To reduce the risks of adverse health effects due to sodium, consult a physician or registered dietitian to plan a healthy diet that reduces the sodium content in your total food intake.

What is the pH (acidity) range of your water?

Water in the distribution system averages 7.2 pH units and ranges from 6.8 to 7.7 pH units. A pH of 7.0 is considered neutral, neither acidic nor basic.

Is there fluoride in your water?

Pennsylvania American Water Company does not add fluoride to your water supply. The naturally occurring fluoride levels are typically at or below 0.1 ppm.

Partnership for Safe Drinking Water Program

In 2000, the Bangor Water Treatment Plant was awarded the prestigious Director's Award under the Partnership for Safe Drinking Water Program. The program is administered by the U.S. Environmental Protection Agency, the Pennsylvania Department of Environmental Protection, and other water related organizations. The award honors utilities for achieving operational excellence by voluntarily optimizing their treatment facility operations and adopting more stringent performance goals than those required by federal and state drinking water standards. The Bangor system has met the voluntary goals of the program for 15 continuous years. In November 2015 the Partnership for Safe Water bestowed the President's Award on Bangor Water Treatment Plant. This award recognizes treatment plants that have achieved the highest possible levels of individual filter turbidity performance goals. We are proud to announce that Pennsylvania American Water's Bangor Water Treatment Plant continued to meet these goals through 2017.



How to Contact Us

Additional copies of this report can be printed directly from this site www.amwater.com/ccr/bangor.pdf. Questions can be presented to our Customer Service Department at 1-800-565-7292. Added information can be gathered by viewing the following links on the Internet:

[Pennsylvania American Water Web Page](#)

[Pa. Department of Environmental Protection Web Page](#)

[United States Environmental Protection Agency Web Page](#)

Safe Drinking Water Hotline: (800) 426-4791

[Center for Disease Control and Prevention Web Page](#)

[American Water Works Association Web Page](#)

Substances Expected to be in Drinking Water

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Pennsylvania American Water's treatment processes are designed to reduce any such substances to levels well below any health concern and the processes are controlled to provide maximum protection against microbial and viral pathogens which could be



QUALITY. ONE MORE WAY WE KEEP LIFE FLOWING.

naturally present in surface and groundwater. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline at (800) 426-4791.

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

Cryptosporidium

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes *Cryptosporidium*, the most commonly-used filtration methods cannot guarantee 100 percent removal. If the organism was detected, current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. Initial monitoring for *Cryptosporidium* was completed in 2007. Based on the results of that first round of *Cryptosporidium* monitoring, no additional treatment was required by the US EPA regulations. The Bangor WTP began a second round of testing of the surface water sources in October of 2017. The results of this sampling isare summarized at the end of this report. This second round of sampling will continue through 2018.

How to Read This Table

In general, start with a **Substance** and read across the table. **Year Sampled** will be in 2017 or earlier depending on the frequency required by the regulations. **MCL** shows the highest level of each substance (contaminant) allowed. **MCLG** is the goal level for that substance (the goal may be set lower than what is allowed). **Highest Amount Detected** represents the highest measured amount (less is better). In some cases compliance is based on calculated values or values other than the **Highest Amount Detected**. In these instances the **Results** are shown with notations that explain the regulatory requirements. **Range** tells the highest and lowest amounts measured. A **Yes** under **Compliance Achieved** means the

Definitions of Terms Used in This Report

AL (Action Level): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.



MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

NA: Not applicable

ND: Not detected

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of the water.

ppm (parts per million): One part substance per million parts water, or milligrams per liter.

ppb (parts per billion): One part substance per billion parts water, or micrograms per liter.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

90th Percentile: The highest concentration of lead or copper in tap water that is exceeded by 10 percent of the sites sampled during a monitoring period. This value is compared to the lead or copper action level (AL) to determine whether an AL has been exceeded.

%: Percent.

<: Less than.

Water Quality Statement

We are pleased to report that during calendar year 2017, the water delivered to your home or business complied with all state and federal drinking water requirements. For your information, we have compiled a list in the table below showing what substances were detected in your drinking water during 2017. The Pennsylvania DEP allows us to monitor for some contaminants less than once per year because the concentration of the contaminants does not change frequently. Some of our data, though representative, are more than one year old. Although all of the substances listed below are under the Maximum Contaminant Levels (MCL) set by the U.S. Environmental Protection Agency and the Pennsylvania DEP, we feel it is important that you know exactly what was detected and how much of each substance was present in the water.

Water Quality Results

Turbidity – A Measure of the Clarity of the Water at the Treatment Facility

Plant	Substance (units)	Year Sampled	MCL	MCLG	Highest Single Measurement	Lowest % of Measurements Meeting TT ¹	Compliance Achieved?	Typical Source
Bangor Plant	Turbidity (NTU) ¹	2017	TT	NA	0.10	100	Yes	Soil runoff

¹ All turbidity readings were below the Treatment Technique requirements for the Plant of not greater than 1 NTU for any single measurement and less than or equal to 0.3 NTU in 95% or more of all samples taken for compliance on a monthly basis. Treatment Technique requirements for turbidity are based on the type of treatment used at the treatment facility; Bangor Plant is classified as "Direct Filtration". Turbidity serves as an indicator of the effectiveness of the filtration process.

Disinfectant Residual – Measured on the Water Leaving the Treatment Facility

Plant	Substance (units)	Year Sampled	MRDL	MRDLG	Lowest Amount Detected	Range Low - High	Compliance Achieved?	Typical Source
Bangor	Chlorine Residual (ppm) ²	2017	4	4	1.14	1.14 – 1.80	Yes	Added as a disinfectant to the treatment process

² All chlorine readings were above the treatment technique requirement of not less than 0.2 ppm for more than four hours.



Groundwater Disinfectant Residual - Measured on the Water Leaving the Treatment Facility

Plant	Substance (units)	Year Sampled	DEP Approved Minimum Disinfectant Residual	Range of Detections ³	Below Required Minimum for More Than 4 Hours	Compliance Achieved?	Typical Source
West Bangor	Chlorine Residual (ppm) ³	2017	0.40	0.41 – 1.54	No	Yes	Water additive used to control microbes

³ All chlorine readings were above the treatment technique requirement of not less than 0.40 ppm for more than four hours.

Substances - Measured on the Water Leaving the Treatment Facilities

Substance (units)	Year Sampled	MCL	MCLG	Highest Amount Detected	Range Low - High	Compliance Achieved?	Typical Source
Nitrate (ppm)	2017	10	10	0.05	0.02 – 0.05	Yes	Runoff from fertilizer use; Leaching from septic tanks; Erosion of natural deposits

Bacterial Results - Measured in the Distribution System

Substance	Year Sampled	MCL ⁷	MCLG	Highest Number of Positive Samples per Month	Compliance Achieved?	Typical Source
Total Coliform Bacteria	2017	TT	NA	0	Yes	Naturally present in the environment

⁷ TT (treatment technique) became effective on April 1st, 2016 and is based on several criteria depending on the presence of coliform bacteria or E. coli in a series of samples. Depending on the type of bacteria and the samples affected, different types of assessment and corrective actions are required. No coliform or E. coli bacteria were detected in any sampling during 2017.

Tap Water Samples: Lead and Copper Results – Measured in the Distribution System

Substance (units)	Year Sampled	Action Level	MCLG	Number of Samples Taken	90 th Percentile	Number of Samples Above Action Level	Compliance Achieved?	Typical Source
Lead (ppb) ⁴	2016	15	0	20	4	0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm) ⁴	2016	1.3	1.3	20	0.20	0	Yes	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

⁴ AL (action level) applies and is based on the 90th percentile value of all samples collected for compliance within the distribution system; 90% of all samples must be equal to or lower than the AL. The maximum lead level detected in any sample was 8 ppb with levels ranging from ND – 8 ppb from all locations sampled.



Disinfection Byproducts Rule 2 Compounds (Measured in the Distribution System)

Substance (units)	Year Sampled	MCL	MCLG	Results	Range Low - High	Compliance Achieved?	Typical Source
Total Trihalomethanes (TTHM) (ppb) ⁵	2017	80	NA	9.9	5.7 – 15.3	Yes	By-product of drinking water chlorination
Haloacetic Acids (HAA5) (ppb) ⁵	2017	60	NA	7.7	4.4 – 10.6	Yes	By-product of drinking water chlorination

⁵ MCL (maximum contaminant level) applies and is based on a Locational Running Annual Average (LRAA) calculated quarterly. Under the Disinfection Byproducts Rule 2 (DBPR2) sample sets are collected each quarter and the levels detected at each location are averaged for each location individually on a running annual basis. Compliance is based on the resulting running annual average at each individual location. The Result represents the highest LRAA for all locations during the year; the calculations used to determine compliance through the year include values from 2016. The highest TTHM and HAA5 results both occurred in the second quarter. The Range represents individual sample results for all locations from all four quarters.

Disinfectant Residual - Measured on the Water in the Distribution System

Substance (units)	Year Sampled	MRDL	MRDGL	Highest Result	Range Low - High	Compliance Achieved?	Typical Source
Free Chlorine Residual (ppm) ⁶	2017	4	4	1.18	1.01 – 1.36	Yes	Added as a disinfectant in the treatment process

⁶ MRDL (maximum residual disinfectant level) applies and is based on a Running Annual Average calculated quarterly. Routine samples were collected monthly with the results from all locations averaged each month. The monthly average results were then used to calculate a Running Annual Average each quarter. The Result represents the highest running annual average calculated quarterly for compliance during the entire year. This occurred during the second quarter of the year; the calculations used to determine compliance through the year include values from 2016. The range represents the range of monthly average results reported for compliance during the entire year.

Cryptosporidium (Measured on Raw Source Water Prior to Treatment) – Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) Round 2 Cryptosporidium Monitoring Results

Substance (units) ¹²	Year Sampled	Highest Average	Range Low - High	Comments
Cryptosporidium (spores/L)	2017	0.030	ND – 0.089	Microbial intestinal parasite associated with animal waste within the watershed.

¹² Cryptosporidium spores were detected at low concentrations in three individual monthly samples collected from several raw water sources from October through December. The highest average concentration of cryptosporidium during this time frame at any single source was 0.030 spores/L and the range of results from all samples collected was ND through 0.089 spores/L. Surface water systems are required to periodically sample their raw water sources to determine if adequate treatment is in place for cryptosporidium. The results of the sampling are used to assign a BIN category to each source with each BIN representing a series of progressive levels of treatment requirements. All surface sources within the system are currently classified as BIN 1 based on the initial monitoring. BIN 1 is the lowest classification requiring no additional treatment. The results here are for the second round of monitoring which will continue through 2018.

