



2015 Annual

Water Quality Report

Huntington District
PWS ID: WV3300608



WEST VIRGINIA
AMERICAN WATER

This report contains important information about your drinking water. We encourage you to read and share this annual Water Quality Report that can be viewed electronically at www.amwater.com/ccr/huntington.pdf



A Message from the West Virginia American Water President

To Our Valued Customer:



Every day across West Virginia, faucets, showers, dishwashers, washing machines and garden hoses are used with little worry about the water's safety, availability, or how it got there in the first place. The fact is, West Virginia American Water's water quality and operations professionals work hard day and night to deliver safe, clean, reliable water service to our customers.

We perform thousands of tests each year to comply with drinking water standards for about 100 regulated substances. All of our eight treatment plants participate in the Partnership for Safe Water Program and seven have been granted Directors Awards for exceptional plant optimization and performance. Less than one percent of all U.S. water utilities – and no other West Virginia water utilities – have achieved this honor. That means our water quality isn't just good – it's exceptional.

Each year, we provide you with our annual water quality report. Like so many years prior, you will find that we continue to supply water that meets or surpasses all state and federal water quality regulations. Our regulatory compliance record is a testament to our commitment to water quality and environmental stewardship. In 2015, West Virginia American Water systems performed 25 times better than the average community water system in West Virginia,

Furthermore, West Virginia American Water invests \$40-50 million each year to replace and upgrade water infrastructure so that you have clean, reliable, affordable water service for your everyday life, for a lifetime. In 2015, we completed the following large infrastructure investment projects:

- Upper Kanawha Valley Pipeline Replacement/Reinforcement –\$6.7 million

- Large Main Replacement Projects – \$6.1 million
- Huntington Sand Removal System – \$3 million
- Weston Plant Automation – \$1.8 million
- Water Storage Tank Rehabilitation –\$1.2 million

It is no simple task to move water from rivers and reservoirs through the water treatment process to our distribution lines and tanks, and finally your home, school or place of work. It requires having the right team of experts and technologies in place, and our scientists, chemists, engineers, operators and maintenance crews are always on the job. Because we invest our dollars responsibly, we provide our water at just over a penny per gallon – an exceptional value for a service that is so essential to our daily lives.

At West Virginia American Water, our customers are at the center of everything we do, and we are committed to providing you with the highest quality drinking water and service possible now and in the years to come. We are proud to be your local water service provider.

Sincerely,

Jeffrey L. McIntyre

Commonly Asked Questions

Is there lead in my water?

Although we regularly test lead levels in your drinking water, it is possible that lead and/or copper levels at your home are higher because of materials used in your plumbing. If present, elevated levels of lead can potentially cause health problems, especially for pregnant women and young children. If you are concerned about possible elevated levels, run your faucet for 30 seconds to 2 minutes before using your water, use cold water for cooking, drinking, or making baby formula; use low lead containing faucets; and when replacing or working on pipes, use lead-free solder. West Virginia American Water



American Water Works Company, Inc., together with its subsidiaries, is referred to as American Water. "West Virginia American Water" and the star logo are the registered trademarks of American Water Works Company, Inc. All rights reserved.

WE CARE ABOUT WATER. IT'S WHAT WE DO.®

remains in full compliance with all of the requirements dealing with lead in drinking water. More information is available from the National Lead Information Center (800) 424-5323, Safe Drinking Water Hotline (800) 426-4791 or at <http://www.epa.gov/safewater/lead>.

How hard is my water?

Hardness is a measure of the concentration of two minerals, calcium and magnesium, naturally present in water. Hardness levels range from 98 to 147 ppm, or 6 to 9 grains per gallon of water.

How much sodium is in my water?

The sodium level is approximately 38 ppm (or mg/L).

What is the pH (acidity) range of my water?

Water in the distribution system averages 7.3 pH units. A pH of 7.0 is considered neutral, neither acidic nor alkaline.

Is there fluoride in my water?

West Virginia American Water adds fluoride to a level of near 0.9 ppm to assist in the prevention of dental cavities.

Where Does My Water Come From?

West Virginia American Water and its customers in the Huntington system are fortunate because we enjoy an abundant water supply from the Ohio River, which is a surface water source. The current treatment plant provided roughly 3.9 billion gallons of water throughout the year to customers in Cabell and Wayne counties in West Virginia and Lawrence County in Ohio. To learn more about our watershed on the internet, go to the U.S. EPA's Search Your Watershed at www.epa.gov/owow/.

Partnership for Safe Drinking Water Program

West Virginia American Water is a member of the national Partnership for Safe Water (an association of water utilities and government) which is committed to providing drinking water quality that is far better than what is required by federal regulation. This facility completed its self-assessment in 1998 and received the "Director's Award" presented by the administrator of the US Environmental Protection Agency. In addition, in 2013, this facility received the prestigious "Fifteen-Year Director's Award" from the US EPA for continuous compliance with the Partnership goals.



Source Water Assessment and Protection

A Source Water Assessment describes the source of drinking water supply for a public water system and potential contaminant sources that could affect that source. The West Virginia Bureau for Public Health developed a Source Water Assessment for the Huntington System under the 1996 amendments to the Federal Safe Drinking Water Act (SDWA). West Virginia American Water has since updated the Source Water Assessment as part of our source water protection planning efforts in

accordance with State regulatory requirements established in 2014 under Senate Bill 373. Information about the Huntington System and Source Water Assessment is included in the public version of the Source Water Protection Plan, which is available online at www.westvirginiaamwater.com under the Water Quality & Stewardship > Source Water Protection menu. A copy can also be obtained by contacting our Source Water Protection Manager at (800) 685-8660.

As a protective measure, the Huntington facility, in conjunction with the Ohio River Valley Water Sanitation Commission (ORSANCO) and other water utilities along the Ohio River and three major tributaries, jointly operate the Organic Detection System for detection and tracking of in-stream chemical spills.

Share This Report

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important information with water users at their location who are not billed customers of West Virginia American Water and therefore do not receive this report directly.

How is My Water Treated and Purified?

Current treatment processes include coagulation and settling followed by filtration and disinfection. An inhibitor is added for corrosion control and fluoridation is provided for reduction of dental cavities. Throughout the process dedicated plant operations and water quality staff continuously monitor and control these plant processes to assure you, our customers, a superior quality water.

Information on the Internet

The U.S. EPA Office of Water and the Centers for Disease Control and Prevention websites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. You may visit these sites or West Virginia American Water's website at the web addresses below:

West Virginia American Water
www.westvirginiaamwater.com

West Virginia Bureau for Public Health
www.wvdhhr.org/oehs

United States Environmental Protection Agency
www.epa.gov/safewater

Safe Drinking Water Hotline: (800) 426-4791

Centers for Disease Control and Prevention
www.cdc.gov

Special Monitoring:

In addition to the unregulated contaminants normally monitored by our facility, in 2014 the Huntington system also sampled for a series of unregulated contaminants in accordance with the Unregulated Contaminant Monitoring



Rule (UCMR3). No additional testing was required. Unregulated contaminants are those that don't yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help the EPA decide whether the contaminants should have a standard. A summary of unregulated compounds detected from the UCMR3 sampling is listed in the water quality tables included here, however specific UCMR3 results are available on request at West Virginia American Water, 4002 Ohio River Road, Huntington, WV 25702 or may be requested by calling (800) 685-8660.

Chromium, a metallic element, is found in rocks, soil, plants, and animals. Chromium is also used in steel making, metal plating, leather tanning, paints, dyes and wood preservatives. The most common forms of chromium in the environment are trivalent (chromium-3), hexavalent (chromium-6) and the metal form, chromium-0. EPA currently regulates chromium-6 as part of the total chromium drinking water standard. New health effects information has become available since the original standard was set, and EPA is reviewing this information to determine whether there are new health risks that need to be addressed. While this review is underway, the EPA suggested that systems begin voluntary monitoring for chromium -6. Additional information can be found at <http://water.epa.gov/drink/info/chromium/index.cfm>. We began voluntary monitoring in your system in 2011 and only had one detection of 0.06 ppb in that year.

Substances Expected to be in Drinking Water

To ensure that tap water is of high quality, U.S. Environmental Protection Agency prescribes regulations limiting the amount of certain substances in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. West Virginia American Water's advanced water treatment processes are designed to reduce any such substances to levels well below any health concern.

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Additional Regulatory Requirements

Cryptosporidium is a microbial pathogen found in surface water throughout the US. Although *Cryptosporidium* can be removed through commonly-used filtration methods, US EPA issued a rule in January 2006 that requires systems with higher *Cryptosporidium* levels in their source water to provide additional treatment. West Virginia American Water's Huntington Treatment Plant monitored for *Cryptosporidium* in its raw water in 2004-2005. Based on the results of this initial *Cryptosporidium* monitoring, no additional treatment was required under this US EPA regulation. In 2015, the Huntington Treatment Plant began a second round of monitoring for *Cryptosporidium* which is scheduled for completion in 2017.

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791 or by calling our Customer Service Center at (800) 685-8660.

How to Read the Data Tables

For your information, we have compiled a list in the adjacent table showing what substances were detected in our drinking water during 2015. Although all of the substances listed are under the Maximum Contaminant Level (MCL) set by the U.S. EPA, we feel it is important that you know exactly what was detected and how much of the substance was present in the water. Please carefully review this report as it provides important information about drinking water and your health. The company remains committed to providing the highest quality water



to our customers. For help with interpreting this table, see the “Table Definitions” section.

Unregulated substances are measured, but maximum allowed contaminant levels have not been established by the government.

Table Definitions and Abbreviations

- **Action Level:** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of disinfectant routinely allowed in drinking water. Addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA:** Not applicable
- **NTU - Nephelometric Turbidity Units:** Measurement of the clarity, or turbidity, of water.
- **pCi/L (picocuries per liter):** Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).
- **ppm (parts per million):** One part substance per million parts water, or milligrams per liter.
- **ppb (parts per billion):** One part substance per billion parts water, or micrograms per liter.

- **ng/L (parts per trillion):** One part substance per trillion parts water, or nanograms per liter.
- **µg/L:** Micrograms per liter or parts per billion.
- **pH:** A measurement of acidity, 7.0 being neutral.
- **Secondary MCL (Secondary Maximum Contaminant Level):** Contaminants levels that may result in cosmetic or aesthetic effects in drinking water.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.

Water Quality Statement

West Virginia American Water, a subsidiary of American Water (NYSE: AWK), is the largest investor-owned water utility in the state, providing high-quality and reliable water services to approximately 577,000 people.

Founded in 1886, American Water (NYSE: AWK) is the largest and most geographically diverse publicly traded U.S. water and wastewater utility company. Marking its 130th anniversary this year, the company employs 6,700 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to an estimated 15 million people in 47 states and Ontario, Canada. More information can be found by visiting www.amwater.com.

The state requires a water utility to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.



Water Quality Results

Regulated Substances (Huntington System)

Substance (units)	Year Sampled	MCLG	MCL	Amount Detected	Range Low-High	Compliance Achieved	Typical Source
Chlorine (ppm) ¹	2015	MRDLG=4	MRDL=4	2.2	0.2 - 3.0	Yes	Water additive to control microbes
Gross Alpha Particle Activity	2011	0	15	0.3	NA	Yes	Radioactive decay of natural deposits
Fluoride (ppm)	2015	4	4	0.9	0.2 - 1.1	Yes	Water additive which promotes strong teeth
Haloacetic Acids (HAAs) (ppb) ²	2015	0	60	41	10 - 65	Yes	By-product of drinking water chlorination
Nitrate (ppm)	2015	10	10	0.78	NA	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Total Trihalomethanes (TTHMs) (ppb) ³	2015	0	80	68	21 - 120	No	By-product of drinking water chlorination
Total Organic Carbon (Removal Ratio) ⁴	2015	NA	TT	1.59	1.00 - 2.86	Yes	Naturally present in the environment
Turbidity (NTU) ⁵	2015	NA	TT	0.29	0.03 - 0.29	Yes	Soil runoff

¹ Amount detected based on a yearly running average of all bacteriological samples collected in the distribution system.

² Based on a yearly running average. The amount detected was determined by averaging the numerical running annual average at each of 8 distribution compliance sites.

³ Based on a yearly running average. The amount detected was determined by averaging the numerical running annual average at each of 8 distribution compliance sites. For the fourth quarter 2015, the running annual average at the Segar Hill/Ceredo site was 84.0 ppb which is above the MCL. As required, a public notice was hand delivered to the 50 customers served in this area informing them of the MCL violation. Actions were immediately taken to return that portion of the system to compliance. The majority of the Huntington customers (as determined at the other 7 distribution sites) remained in compliance for the entire year.

⁴ The Treatment Technique (TT) is met if the TOC Removal Ratio (based on a four quarter running annual average) is greater than or equal to 1.0.

⁵ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration. A minimum of **100%** of all samples taken to measure turbidity met the treatment technique requirement.

Bacterial Results (from the Distribution System)

Substance (units)	Year Sampled	MCLG	MCL	Highest Percentage Detected	Compliance Achieved	Typical Source
Total coliform (% Positive samples)	2015	0	5% Positive samples	0.1%	Yes	Bacteria naturally present in the environment

Regulated Substances: Lead and Copper Results (at the customer's tap)

Substance (units)	Year Sampled	MCLG	Action Level	Amount Detected 90 th Percentile	Number of Samples	Homes Above Action Level	Compliance Achieved	Typical Source
Copper (ppm)	2015	1.3	1.3	0.187	30	0	Yes	Corrosion of household plumbing
Lead (ppb)	2015	0	15	2	30	0	Yes	Corrosion of household plumbing

Unregulated Substances-Measured on Water Leaving the Treatment Facility

Substance (units)	Year Sampled	Average Results	Range Low-High	Secondary MCL	Typical Source
Sulfate (ppm)	2015	57	NA	250	Mineral that occurs naturally in the soil
Zinc (ppm)	2015	0.30	0.25 - 0.37	5	Element that occurs naturally in the water; Constituent of corrosion control additive.
Chloride (ppm)	2015	56	NA	250	Mineral that occurs naturally in the soil, road salt, water softeners
Magnesium (ppm)	2015	9	NA	NA	Mineral that occurs naturally in the soil



Additional Water Quality Parameters of Interest

This table shows average levels of additional water quality parameters which are often of interest to consumers. Values shown here are averages of operating data for 2015. Values may vary from day to day. There are no health-based limits for these substances in drinking water.

Additional Constituents

Substance (units)	Year Sampled	Average Amount Detected	Range Low-High
Alkalinity, Total (ppm)	2015	65	47 - 78
Hardness, Total (ppm)	2015	127	98 - 147
pH (standard units)	2015	7.3	7.0 - 7.8



There's a lot more to your water bill than just water.

When you turn on the tap, it's easy to see what your water bill buys. What's not as easy to see is what it takes to bring that water to your home. The miles of pipeline hidden below the ground. The facilities that draw water from the source. The plant where it's treated and tested. The scientists, engineers, and maintenance crews working around the clock to make sure that water is always there when you need it. Your water payments are helping to build a better tomorrow by supporting needed improvements that will keep water flowing for all of us—today and well into the future. All for about a penny a gallon.

AT ABOUT A PENNY PER GALLON WATER IS A GREAT VALUE™ **WE CARE ABOUT WATER. IT'S WHAT WE DO. FIND OUT WHY YOU SHOULD, TOO, at amwater.com.**

© 2012 American Water. "American Water" and the star logo are the registered trademarks of American Water Works Company, Inc. All rights reserved.



WE CARE ABOUT WATER. IT'S WHAT WE DO.®