



2014 Annual Water Quality Report

West Placer
PWS ID: 3110150



A Message from California American Water President Rob MacLean

To Our Valued Customer:

As California enters our 4th year of serious drought, water is more precious now than ever.

This report includes information about the quality of the water we provide to our customers. As you read through our Annual Water Quality Report, you will see that we continue to supply water that meets or surpasses all state and federal water quality standards. Better yet, the price you pay for this high-quality water service remains about one penny per gallon.

This is an exceptional value when you consider the facilities and technology needed to draw water from the source and treat it, along with miles and miles of pipeline hidden below the ground to bring water to your tap. What's more, our plant operators, water quality experts, engineers and maintenance crews work around the clock to make sure that quality water is always there when you need it.

Delivering reliable, high-quality water service also requires significant investment to maintain and upgrade aging facilities. In 2014 alone, we invested more than \$84 million in local infrastructure across California.

Because water is essential for public health, fire protection, economic development and overall quality of life, California American Water's employees are committed to ensuring that quality water keeps flowing not only today but well into the future. We hope you agree that water is worth conserving, now more than ever.

For more information about the drought, and how we can help you save water, please visit www.californiaamwater.com/drought.

Sincerely,

Robert G. MacLean
President

This report contains important information about your drinking water. Translate it, or speak with someone who understands it at (888) 237-1333.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien al (888) 237-1333.

Ntawm no yog ib co lus qhia tseem ceeb heev txog koj cov dej seb huv npaum li cas. Yog tias koj xav tau kev pab txhais cov lus qhia no, thov hu rau peb ntawm (888) 237-1333.

這是關於您的水質的十分重要的資訊。如果您需要幫助翻譯此資訊請致電(888) 237-1333 與我們聯繫。

आपके पानी की गुणवत्ता के बारे में यह बहुत महत्वपूर्ण सूचना है। यदि इस सूचना के अनुवाद के लिए आपको सहायता की जरूरत हो, तो कृपया (888) 237-1333 पर हमें काल करें।

Это очень важная информация о качестве Вашей воды. Если Вам требуется перевод этой информации, позвоните нам по телефону (888) 237-1333.

Ito ay isang napakahalagang impormasyon tungkol sa kalidad ng iyong tubig. Kung iyang kailangan ng tulong sa pagsalin ng impormasyon na ito, mangyaring tumawag sa amin sa (888) 237-1333.

Đây là thông tin rất quan trọng về chất lượng nước của quý vị. Nếu quý vị cần thông dịch thông tin này, xin gọi chúng tôi theo số (888) 237-1333.

Our Commitment to Quality

Once again, we proudly present our Annual Water Quality Report. This document covers compliance testing completed through December 2014. We are pleased to tell you that our compliance with state and federal drinking water regulations remains exemplary. As in the past, we are committed to delivering the best quality drinking water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all our water users.

About California American Water

California American Water, a subsidiary of American Water (NYSE: AWK), provides high-quality and reliable water and/or wastewater services to more than 600,000 people.

About American Water

Founded in 1886, American Water (NYSE: AWK) is the largest and most geographically diverse publicly traded U.S. water and wastewater utility company. With headquarters in Voorhees, N.J., the company employs approximately 6,400 dedicated professionals who provide drinking water, wastewater and other related services to an estimated 15 million people in more than 45 states and parts of Canada. More information can be found at www.amwater.com.

What is a Consumer Confidence Report (CCR)?

To comply with state and U.S. Environmental Protection Agency (USEPA) regulations, California American Water issues a report annually describing the quality of your drinking water. This report is also called an Annual Water Quality Report and the purpose of this report is to raise your understanding of drinking water and awareness of the need to protect your drinking water sources. In 2014, we conducted hundreds of tests at numerous sampling points in your water system, all of which were below state and federal maximum allowable levels. This report provides an overview of last year's water quality. It includes details about where your water comes from and what it contains. The data presented in this report is a combination of data from our nationally recognized main water quality lab, and commercial laboratories, all certified in drinking water testing by the State Water Resources Control Board, Division of Drinking Water (formerly California Department of Public Health).

If you have any questions about this report or your drinking water, please call our Customer Service Center at (888) 237-1333

Share this Report

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important water quality information with water users at their location who are not billed customers of California American Water and therefore do not receive this report directly.

About Your Water

Water in the West Placer system is purchased from the Placer County Water Agency through the City of Roseville. This water comes from the Folsom Lake Reservoir. Drinking water treatment technologies used by the City of Roseville include conventional treatment (coagulation, sedimentation, filtration, and disinfection). The pH of the water is adjusted to control corrosion in the distribution system, and fluoride is added to promote dental health.

Notice of Source Water Assessment

A source water assessment was conducted for the City of Roseville's water supply from Folsom Lake in December 2008. The source is considered most vulnerable to the following activities that are associated with contaminants detected in the water supply: Folsom Lake State Recreation Area facilities (marina, restrooms, recreational areas, parking lots, and storm drains) and residential sewer and septic systems.

Although not associated with any detected contaminants, the source is also considered vulnerable to the following activities: illegal activities and dumping; fertilizer, pesticide and herbicide application; and high-density housing developments.

A copy of the complete source water assessment may be viewed at the California Department of Public Health, 1616 Capitol Avenue, Sacramento, CA 95899-7413.



You may request that a summary of the assessment be sent to you by contacting the City of Roseville Water Department at (916) 774-5750

Information Regarding Contaminants Detected In Your Water **Cryptosporidium Monitoring**

Cryptosporidium is a microbial pathogen found in surface waters throughout the U.S. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100% removal. Monitoring indicates the presence of these organisms in source water and/or finished water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their health care provider regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water. You can obtain more information on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

Radon

Radon is a radioactive gas that you cannot see, taste, or smell. It is found throughout the United States. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water while showering, washing dishes, or doing other household activities with water. Compared to radon entering the home through soil, radon entering the home through tap water in most cases will be a minor source of radon in indoor air. Radon is a known human carcinogen.



Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air inside. Testing is inexpensive and easy. You should pursue radon removal for your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that are not too costly. For additional information, call your state radon program at (800) 745-7236, the USEPA Safe Drinking Water Hotline at (800) 426-4791, or the National Safety Council's Radon Hotline at (800) SOS-RADON.

Fluoride

Fluoride is a naturally occurring substance. It can be present in drinking water from two sources: 1) by nature when groundwater comes into contact with fluoride-containing minerals naturally present in the earth; or 2) by a water purveyor through the addition of fluoride to the water before the water is put in the distribution system. In the West Placer system, fluoride is added to the water supply at concentrations based on state fluoride regulations managed by the State Water Resources Control Board, Division of Drinking Water and the Office of Oral Health. According to these agencies, when fluoride is present in drinking water at optimal levels, it has been shown to promote oral health by preventing tooth decay.

What are the Sources of Contaminants?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Groundwater sources are typically less susceptible to surficial contaminants than surface water systems.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board, Division of Drinking Water prescribe regulations that limit the amount

of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

Source Water Protection Tips for Consumers

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water sources in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water sources.
- Pick up after your pets.
- Dispose of chemicals properly; take used motor oil and antifreeze to a recycling center. (www.wpwma.com/hhw.html)
- Do not dispose of unused medications down the drain.
- Use environmentally friendly soaps and detergents when washing your vehicles.

Educational Information – Special Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. You can obtain more information about contaminants and potential health effects by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune



system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA and the Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. California American Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been idle for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

How to Contact Us

If you have any questions about this report, your drinking water, or service, please call California American Water's Customer Service toll free at (888) 237-1333.

Water Information Sources

California American Water
www.californiaamwater.com

State Water Resources Control Board, Division of Drinking Water
www.waterboards.ca.gov/drinking_water/programs/index.shtml

United States Environmental Protection Agency (USEPA)
www.epa.gov/safewater

Safe Drinking Water Hotline

(800) 426-4791

Centers for Disease Control and Prevention

www.cdc.gov

American Water Works Association

www.awwa.org

Water Quality Association

www.wqa.org

National Library of Medicine/National Institute of Health

www.nlm.nih.gov/medlineplus/drinkingwater.html

How to Read This Table

California American Water conducts extensive monitoring to ensure that your water meets water quality standards. The results of our monitoring are reported in the adjacent tables. While some monitoring was conducted in 2014, certain substances are monitored less than once per year because the levels do not change frequently. For help with interpreting this table, see the "Definition of Terms" section.

Starting with a **Substance**, read across. **Year Sampled** is usually 2014 or the most recent data from a prior year. **MCL** shows the highest level of the substance (contaminant) allowed. **PHG** (or **MCLG**) is the goal level for that substance (this may be lower than what is allowed). **Average Amount Detected** represents the (calculated) average level of that substance from the drinking water sources that California American Water used in 2014. **Range** tells the highest and lowest amounts measured. A "No" under **Violation** indicates regulatory requirements were met. **Major Sources in Drinking Water** tells where the substance usually originates.

Definitions of Terms Used in This Report

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, that a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

micromhos per centimeter ($\mu\text{mhos/cm}$): A measure of electrical conductance.

Million fibers per liter (MFL): The number of asbestos fibers (in millions) per liter that are greater than 10 microns in length.

NA: Not applicable

ND: Not detected

Nephelometric Turbidity Units (NTU): Measurement of the clarity, or turbidity, of the water.

Notification Level (NL): The concentration of a contaminant, which, if exceeded, requires notification to the State Water Resources Control Board, Division of Drinking Water and the consumer. Not an enforceable standard.

NR: Not reported

parts per billion (ppb): One part substance per billion parts water, or micrograms per liter.

parts per million (ppm): One part substance per million parts per water, or milligrams per liter.

pH: A measurement of acidity, 7.0 being neutral.

picocuries per liter (pCi/L): Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

RAA: Running Annual Average

Regulatory Action Level (RAL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Secondary Maximum Contaminant Level (SMCL): SMCLs are set to protect the aesthetic properties of drinking water (odor, taste and appearance).

TOC: Total Organic Carbon

TON: Threshold Odor Number


Total Dissolved Solids: An overall indicator of the amount of minerals in water.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Water Quality Statement

Last year, as in years past, your tap water met USEPA and state drinking water standards. California American Water vigilantly safeguards its water supplies, and once again we are proud to report that our system did not violate any state or federal water quality standards.



There's a lot more to your water bill than just water.

When you turn on the tap, it's easy to see what your water bill buys. What's not as easy to see is what it takes to bring that water to your home. The miles of pipeline hidden below the ground. The facilities that draw water from the source. The plant where it's treated and tested. The scientists, engineers, and maintenance crews working around the clock to make sure that water is always there when you need it. Your water payments are helping to build a better tomorrow by supporting needed improvements that will keep water flowing for all of us—today and well into the future.

Water Quality Results

Regulated Substances

Substance, (units)	Year Sampled	MCL	PHG (MCLG)	West Placer*			City of Roseville		Violation	Major Sources In Drinking Water
				Average Amount Detected	Range		Average Amount Detected	Range		
					Low	High				
Control of Disinfection By-Product Precursors (TOC) (ppm)	2014	Treatment requirement if average TOC >2	NA	NA	NA		0.99	ND - 1.3	No	Various natural and man-made sources

Regulated Substances-Distribution System Monitoring

Substance, (units)	Year Sampled	MCL	PHG (MCLG)	West Placer*			City of Roseville		Violation	Major Sources In Drinking Water
				Average Amount Detected	Range		Average Amount Detected	Range		
					Low	High				
Chlorine (ppm)	2014	MRDL = 4.0	MRDLG = 4.0	0.42	0.28	0.56	--	--	No	Treatment chemical used to disinfect drinking water
Fluoride (ppm) ¹	2014	0.7 – 1.3 ²	NA	0.62	ND	0.80	0.69	ND - 1.29	No	Water additive which promotes strong teeth
Haloacetic Acids (ppb) ³	2014	60	NA	32	18	40	--	--	No	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb) ³	2014	80	NA	64	53	75	--	--	No	By-product of drinking water disinfection

¹ The City of Roseville adjusts the natural level of fluoride in our water supply to be within the California Department of Public Health's recommended Fluoride Control Range.

² Fluoride Control Range, not an MCL.

³ Average Amount Detected is the Highest Running Annual Average

Secondary Substances

Substance, (units)	Year Sampled	SMCL	West Placer*			City of Roseville		Violation	Major Sources In Drinking Water
			Average Amount Detected	Range		Average Amount Detected	Range		
				Low	High				
Color (units)	2012-2013	15	ND	ND		5	ND - 5	No	Naturally occurring organic material
Chloride (ppm)	2012-2013	500	4	4		2.6	1.6 - 81	No	Runoff/leaching from natural deposits; Seawater influence
Odor (TON)	2012-2013	3	ND	ND		1	ND - 1	No	Naturally occurring organic material
Specific Conductance (µmhos/cm)	2012-2013	1600	95	95		49	42 - 610	No	Substances that form ions when in water; Seawater influence
Sulfate (ppm)	2012-2013	500	6.7	6.7		0.4	ND - 29	No	Runoff/leaching from natural deposits; Industrial wastes
Total Dissolved Solids (ppm)	2012-2013	1000	63	63		30	25 - 400	No	Runoff/leaching from natural deposits
Turbidity (NTU)	2012, 2014	5	ND	ND		0.03	0.02 - 0.11	No	Runoff and leaching from fertilizer use; Leaching from septic tanks and sewage; Erosion of natural deposits

*Water quality monitoring performed by California American Water where the City of Roseville water enters the West Placer system

Turbidity – A Measure of the Clarity of the Water (at the City of Roseville Treatment Facility)

Plant	Year Sampled	MCL	PHG (MCLG)	Highest Single Measurement	Violation	Typical Source
Turbidity (NTU)	2014	TT = 1.0 NTU	NA	0.11	No	Soil runoff
		TT = percentage of samples < 0.3 NTU		100%		

Lead and Copper (tap water samples from the West Placer system only)

Substance, (units)	Year Sampled	Action Level	PHG (MCLG)	Number of Samples	Amount Detected (90 th Percentile)	Homes Above Action Level	Violation	Typical Source
Copper (ppm)	2013	1.3	0.3	17	ND	0	No	Internal corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2013	15	0.2	17	ND	0	No	Internal corrosion of household plumbing systems; Erosion of natural deposits; Discharges from industrial manufacturers

Additional Water Quality Parameters of Interest

This table shows average levels of additional water quality parameters which are often of interest to consumers. The averages shown here are calculated from the levels detected. Values may vary from day to day. There are no health-based limits for these substances in drinking water.

Additional Constituents

Substance, (units)	Year Sampled	West Placer*		City of Roseville	
		Average Amount Detected	Range	Average Amount Detected	Range Low-High
Alkalinity as CaCO ₃ (ppm)	2012, 2014	30	30	28	22 - 150
Calcium (ppm)	2012-2013	5.9	6	4.8	4.3 - 38
Magnesium (ppm)	2012-2013	1.5	2	1.3	1.2 - 12
pH	2012-2013	7.9	8	7.5	7.5 - 8.0
Silica (ppm)	2012	ND	ND	--	--
Sodium (ppm)	2012-2013	9.4	9	2.7	2 - 66
Total Hardness as CaCO ₃ (ppm)	2012-2013	21	21	18	16 - 140