



2018 Annual

Water Quality Report

Central Division
Ford Hampton Area
PWSID: KY0340250



Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

A Message from the Kentucky American Water President

To Our Valued Customer:

Kentucky American Water is proud to be your local water service provider, and I am pleased to share with you good news about the quality of your drinking water. Each year, we provide you with our Annual Water Quality Report that provides information about where your water comes from, the results of water testing, and information about what was found during that testing.



Quite a lot goes into bringing that water to your home. The miles of pipeline hidden below the ground. The facilities that draw water from the source. The plant where it's treated and tested. Our treatment plant operators, water quality experts, engineers, and maintenance crews working around the clock to make sure that water is always there when you need it. Delivering high-quality, reliable water service to your tap around the clock also requires significant investment in our water infrastructure to upgrade aging facilities. In fact, we invest more than \$20 million in capital improvements each year. We are proud that we continue to supply water for **about a penny per gallon—an exceptional value.**

We do this because we believe we're delivering more than just water service. We deliver a key resource for public health, fire protection, economic development and overall quality of life. Our job is to ensure that quality water keeps flowing not only today, but well into the future. It's part of our commitment to you and the communities we serve.

We hope you agree that it's worth every penny and worth learning more about. Please take the time to review this report. It provides details about the source and quality of your drinking water using the data from water quality testing conducted for your local water system from January through December 2018.

We appreciate the opportunity to serve you.

Sincerely,

Nick O. Rowe
President, Kentucky American Water

About Kentucky American Water

Kentucky American Water, a subsidiary of American Water (NYSE: AWK), is the largest investor-owned water utility in the state, providing high-quality and reliable water and/or wastewater services to approximately half a million people.

With a history dating back to 1886, American Water is the largest and most geographically diverse U.S. publicly traded water and wastewater utility company. The company employs more than 7,100 dedicated professionals who provide regulated and market-based drinking water, wastewater and other related services to more than 13 million people in 46 states and Ontario, Canada. American Water provides safe, clean, affordable and reliable water services to our customers to make sure we keep their lives flowing. For more information, visit amwater.com and follow American Water on [Twitter](#), [Facebook](#) and [LinkedIn](#).

Your Drinking Water Supply

The sources of water for both drinking and bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. When water travels over the surface of the land or through the ground it dissolves naturally occurring minerals (possibly radioactive material) and picks up organic material from the presence of animals or humans. The following contaminants may be present in source water because of this process:

- **Microbial Contaminants**, such as viruses and bacteria from sewage, agricultural livestock operations or wildlife.
- **Inorganic Contaminants**, such as salts and metals that occur naturally or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and Herbicides**, which come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- **Organic Chemical Contaminants (including synthetic and volatile organic chemicals)**, which are by-products of industrial processes and petroleum production, and may come from gas stations, urban storm water runoff and septic systems.
- **Radioactive Contaminants**, which occur naturally or result from oil and gas production and mining activities.

The drinking water supply for Kentucky American Water's Central Division Ford Hampton Area is surface water from pool 10 of the Kentucky River and the Carroll E. Ecton Reservoir. Pool 10 of the Kentucky River runs between Clark and Madison counties beginning at the lock and dam located at Fort Boonesboro and extending 25 miles upstream. The Carroll E. Ecton Reservoir is located on Water Works Road in southern Clark County. This surface water provides the primary source of drinking water produced by Winchester Municipal Utilities (WMU), Public Water System Identification Number KY0250473, and distributed by Kentucky American Water to our Ford Hampton customers.

What Can You Do?

Quality drinking water starts upstream. Everyone can help maintain and improve drinking water supplies:

- Eliminate excess use of fertilizers and pesticides, they contain hazardous chemicals that can reach our source water.
- Dispose of medicine, household chemicals, oils and paints at proper waste collection sites. Materials can pollute water ways if poured down the drain, flushed down the toilet, or dumped on the ground. Contact your county waste authority to find out how to properly dispose of these materials.
- Check for leaks from automobiles and heating fuel tanks. Clean up any spills using an absorbent material like cat litter. Sweep up the material and put it in a sealed bag in the trash.
- Volunteer with watershed groups in your area.
- Pick up after your pets.
- Remember that storm drains dump directly into local water bodies.

What Are We Doing?

Our vision is Clean Water for Life. Our priority is to provide reliable, quality drinking water for our customers. Protecting the source of our supply is an important part of that mission. We also work to understand and reduce potential risks to your drinking water supply.

The Kentucky Division of Water approved a Source Water Assessment and Protection Plan for Winchester Municipal Utilities in 2003. An analysis of the susceptibility of the Winchester water supply to contamination indicates that this susceptibility is generally moderate, but there are a few areas of high concern. Several highway bridges, a segment of railroad, areas of row crops, three active Superfund Sites, three solid waste generators and/or transporters, and impaired streams occur in the immediate area of Winchester's Kentucky River intake. An accidental release of toxic materials from a bridge or railroad could pose an immediate threat to Winchester's Kentucky River intake. There are numerous permitted activities and other potential contaminant sources of moderate concern within the watershed. These potential contaminant sources include everything from large capacity septic systems, to major roads, to underground storage tanks, to Tier II hazardous chemical users. A copy of the completed Source Water Assessment and Protection Plan may be viewed by calling the Watershed Management Branch of the Kentucky Division of Water at 502-564-3410.

Other efforts underway to protect our shared water resources include:

- **Community Involvement:** We have a proactive public outreach program to help spread the word and get people involved. This includes school education, contests, and other community activities.
- **Environmental Grant Program:** Each year, we offer funding for innovative, community-based environmental projects that improve, restore or protect watersheds supplies in our local communities.
- **Pharmaceutical Collection:** We sponsor the biannual Drug Take Back event as well as a drop box location at Lexington Police Department lobby for residents to safely dispose of unwanted drugs for free. This helps keep pharmaceutical products from entering water supplies.
- **Backflow Prevention Program:** Ensures the proper installation and maintenance of thousands of backflow prevention devices throughout our system. These devices ensure hazards originating on customers' properties and from temporary connections do not impair or alter the quality of water in our distribution system. For more information about Kentucky American Water's backflow prevention program, please visit our web site at www.kentuckyamwater.com, or contact the Cross Connection department at KAW.cc@amwater.com or (859)268-6310.

You Can Be Involved in Matters That Affect Your Water

Kentucky American Water welcomes your comments and questions regarding your water. To provide feedback on decisions that may affect the quality of your water, for questions about your water or this report, or to obtain additional copies of this report, please call our Customer Service Center at 800-678-6301 or 859-269-2386 ext 6 for Dorothy Rader, Manager, Water Quality and Environmental Compliance.

As a customer of a utility regulated by the Kentucky Public Service Commission, you have the opportunity to participate in periodic public hearings regarding Kentucky American Water. For more information about this process, please refer to the Public Service Commission website at <http://psc.ky.gov/> or call 800-772-4636.



A Proud Master Member of the Kentucky EXCEL Program

The Kentucky Department for Environmental Protection administers a voluntary program that is open to anyone who wishes to improve and protect Kentucky's environment beyond regulatory requirements. The Master membership is the highest of the four membership levels, requiring members to demonstrate comprehensive environmental management planning; undergo an independent, third-party assessment of compliance; and commit to complete and report on at least four voluntary projects that will benefit Kentucky's environment. Kentucky American Water is proud to participate in this program at the Master level, and was the first utility in the state to do so.

Substances Expected to Be in Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

To ensure tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations limiting the amount of certain substances in water provided by public water systems. The U.S. Food and Drug Administration establishes limits for contaminants in bottled water that must provide the same protection for public health.

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information on the Internet

The U.S. Environmental Protection Agency, Centers for Disease Control and the Kentucky Division of Water web sites provide a substantial amount of information relating to water sources, water conservation, and public health. You may visit these sites at the addresses below:

U.S. Environmental Protection Agency
www.epa.gov/ground-water-and-drinking-water

Centers for Disease Control and Prevention
www.cdc.gov

Kentucky Division of Water
www.water.ky.gov

What is *Cryptosporidium*?

Cryptosporidium is a microbial pathogen found in surface water throughout the United States. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. People with severely weakened immune systems have a risk of developing life-threatening illness. We encourage such individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water.

Winchester Municipal Utilities began a second round of 24 consecutive months of monitoring for *Cryptosporidium* in their source waters in October 2016. Sample results were as follows:

- 2016: *Cryptosporidium* was not detected in any of the 3 source water samples
- 2017: *Cryptosporidium* was detected in 1 of 12 source water samples

Winchester Municipal Utilities is required to monitor the source of your drinking water for *Cryptosporidium* in order to determine whether treatment at the water treatment plant is sufficient to adequately remove *Cryptosporidium* from your drinking water.

Special Information about Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Kentucky American Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Availability of Monitoring Data for Unregulated Contaminants for Kentucky American Water

Our water system has sampled for a series of unregulated contaminants, commonly known as UCMR4. Unregulated contaminants are those that don't yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. Kentucky American Water completed testing for cyanotoxins in 2018 which includes, microcystins, anatoxin-a, and cylindrospermopsin with no detections in 2018. As our customers, you have a right to know that this data is available. If you are interested in examining the results, please contact Dorothy Rader, Manager, Water Quality and Environmental Compliance at 859-269-2386 ext 6 or 2300 Richmond Road, Lexington KY 40502

This notice is being sent to you by Kentucky American Water, State Water System ID#: KY0340250
Date distributed: 06/15/2019.

Water Quality Testing

Kentucky American Water conducts extensive monitoring to ensure that your water meets all water quality standards. The following tables contain results of our monitoring. While most monitoring occurred in 2018, certain substances are monitored less than once per year because the levels do not change frequently. We believe it is important that you know exactly what is in your water and how much of the substance is present in the water.

How to Read This Table

Start by finding a **Substance**, and then read across to find the information about that substance. The **Year Sampled** is usually in 2018 or the prior year. **MCL** shows the highest level of substance (contaminant) allowed. **MCLG** is the goal level for that substance (this may be lower than what is allowed). **Highest Value** (results) represents the measured amount (less is better). **Range** tells the highest and lowest amounts measured. **Typical Source** tells where the substance usually originates.

Definitions of Terms Used in This Report

- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

- **Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **NA:** Not applicable
- **ND:** Not detected
- **NTU (Nephelometric Turbidity Units):** A measurement of the clarity, or turbidity, of the water.
- **pCi/L (picocuries per liter):** Measure of radioactivity in water.
- **ppb (parts per billion):** One part substance per billion parts water, or micrograms per liter.
- **ppm (parts per million):** One part substance per million parts water, or milligrams per liter.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.

Water Quality Results

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than a year old.

Regulated Substances (Measured on the Water Leaving the Treatment Facility)

Substance (units)	Year Sampled	MCL	MCLG	Winchester Municipal Utilities		Violation Yes/No	Typical Source
				Highest Value	Range Low-High		
Turbidity (NTU) ¹	2018	TT	NA	0.21	100% Lowest Monthly	No	Soil runoff
Beta or photon emitters (pCi/L) ²	2014	50	0	3.9	3.9 - 3.9	No	Decay of natural and man-made deposits
Alpha emitters (pCi/L) ²	2014	15	0	2.6	2.6 - 2.6	No	Erosion of natural deposits
Combined Radium (pCi/L) ³	2014	5	0	1.53	1.53 - 1.53	No	Erosion of natural deposits
Barium (ppm)	2018	2	2	0.022	0.022 - 0.022	No	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	2018	4	4	0.97	0.97 - 0.97	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (ppm)	2018	10	10	0.34	0.34 - 0.34	No	Runoff from Fertilizer use; Leaching from septic tanks; Sewage; Erosion of natural deposits
Total Organic Carbon (ppm) ⁴	2018	TT	NA	1.47	1.01 - 3.32	No	Naturally present in the environment

Regulated Substances (Measured in the Distribution System by Kentucky American Water)

Substance (units)	Year Sampled	MCL	MCLG	Highest Running Annual Average	Range Low-High	Violation Yes/No	Typical Source
Total Trihalomethanes (ppb) ⁵	2018	80	NA	60	16 - 110.7	No	By-product of drinking water disinfection
Haloacetic Acids (ppb) ⁵	2018	60	NA	47	1.8 - 54.2	No	By-product of drinking water disinfection
Chlorine (ppm) ⁶	2018	4	4	0.85	0.40 - 1.45	No	Water additive used to control microbes

Maximum Contaminant Level (MCL's) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Regulated Substances (Measured at the Customer's Tap by Kentucky American Water)

Substance (units)	Year Sampled	Action Level	MCLG	90 th Percentile	Range Low-High	Number of Samples	Number of Samples Above Action Level	Violation Yes/No	Typical Source
Copper (ppm) ⁷	2018	1.3	1.3	0.232	ND - 0.449	64	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb) ⁷	2018	15	0	ND	ND - 0.001	64	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

¹ **Turbidity:** is the clarity of water. It is measured as an indicator of water quality and the effectiveness of the filtration system. Compliance with the turbidity Treatment Technique (TT) is achieved when 95% of four-hour filtered water readings are 0.3 NTU or lower and no readings are greater than 1 NTU. Lowest monthly percentage of samples meeting the turbidity limit = 100%. Turbidity data are from samples collected by Winchester Municipal Utilities.

² **Alpha and Beta or Photon Emitters:** The MCL for beta or photon emitters is 4 mrem/year (millirems per year is a measure of radiation absorbed by the body). The results in the table are reported in picoCuries/liter (pCi/L). EPA considers 50 pCi/L the level of concern for beta emitters. Winchester Municipal Utilities sampled for Alpha and Beta or Photon Emitters in 2014.

³ **Combined Radium:** Radium-226 and Radium-228 concentrations added together.

⁴ **Total Organic Carbon:** Although the concentration listed is ppm, the values shown are ratios used to determine compliance. Compliance with the TOC Treatment Technique (TT) requirement is based on the lowest running annual average (RAA) of the monthly ratios of the % TOC treatment removal achieved compared to the required removal. A minimum annual average ratio of 1.00 is required. Total organic carbon data are from Winchester Municipal Utilities. The number reported in the Highest Value column is actually the lowest RAA, calculated quarterly, for the year.

⁵ **Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAAs):** Compliance is based on the highest LRAA (locational running annual average) that is calculated quarterly. The highest quarterly LRAA is the measured value in the table. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

⁶ **Chlorine:** A public water system shall be in compliance with the MRDL if the RAA (running annual average) of monthly averages of samples taken in the distribution system computed quarterly is less than or equal to the MRDL.

⁷ **Lead and Copper:** Compliance is achieved when at least 90% of samples collected from water standing in contact with plumbing for at least 6 hours are below the Action Level. Lead and copper results are from samples collected by Kentucky American Water. The 90th percentile for lead was below the detection limit.